


750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Report

for

Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg.” Room 308
Honolulu, HI 96843
Attention: Erwin Kawata
Fax: 808-550-5018



Utah ELCP CA00006

DEB: Debbie L Frank
Project Manager

Report: 982678
Project: RED-HILL
Group: Red-Hill Expanded List (Albuquerque+)

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all **TNI 2016 and ISO/IEC 17025:2017** requirements unless noted under the individual analysis.

* As applicable, this report consists of the cover page, State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	NE-OS-21-13
Arkansas	CA00006	Nevada	CA00006
California	2813	New Hampshire *	2959
Colorado	CA00006	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	CA00006
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	21-008R	Ohio - 537.1	87786
Hawaii	CA00006	Oregon *	4034
Idaho	CA00006	Pennsylvania *	68-00565
Illinois	200033	Puerto Rico	CA00006
Indiana	C-CA-01	Rhode Island	LAO00326
Iowa – Asbestos	413	South Carolina	87016
Kansas *	E-10268	South Dakota	CA11320
Kentucky	90107	Tennessee	TN02839
Louisiana *	LA008	Texas *	T104704230-20-18
Maine	CA00006	Utah (Primary AB) *	CA00006
Maryland	224	Vermont	VT0114
Marianas Islands	MP0004	Virginia *	460260
Massachusetts	M-CA006	Washington	C838
Michigan	9906	EPA Region 5	CA00006
Mississippi	CA00006	Los Angeles County Sanitation Districts	10264

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025:2917 Accredited Method List

The test listed below are accredited and met the requirements of ISO/IEC 17025 as verify by A2LA.

Refer to our certificates and scope of accreditations (no. 5890-1 and 5890-2) found at:

<https://www.eurofinsus.com/Eaton>

Test(s)	Method(s)	Potable Water *	Waste Water	Test(s)	Method(s)	Potable Water *	Waste Water
Enterococci	Enterolert	x	x	Gross Alpha coprecipitation	SM 7110 C	x	x
Escherichia coli (Enumeration)	SM 9221 B.1 SM 9221 F	x		Hardness	SM 2340 B	x	x
Fecal Coliform (P/A and Enumeration)	SM 9221 C (MTF/EC), SM 9221 E (MTF/EC)	x	x	Hexavalent Chromium	EPA 218.6,	x	x
Fecal Streptococci and Enterococci	SM 9230 B	x	x	Hexavalent Chromium	EPA 218.7,	x	
Heterotrophic Bacteria	SM 9215 B	x		Hexavalent Chromium	SM 3500-Cr B		x
Legionella	Legiolert®	x		Inorganic Anions and DBPs	EPA 300.0	x	x
Pseudomonas aeruginosa	Idexx Pseudalart	x		Norganic Anions and DBPs	EPA 300.1	x	
Total Coliform (P/A and Enumeration)	SM 9221A, SM 9221B, SM 9221 C	x	x	Kjeldahl Nitrogen	EPA 351.2		x
Total Coliform, Total Coliform with Chlorine Present	SM 9221 B	x	x	Metals	EPA 200.7, EPA200.8	x	x
Total Coliform/E. coli (P/A and Enumeration, Idexx Colilert, Idexx Colilert 18, Colisure)	SM 9223	x		Nitrosamines	EEA-Agilent 521.1 (GCMS-24250)	x	
Total Microcystins and Nodularins	EPA 546	X		Nitrate/Nitrite Nitrogen	EPA 353.2	x	x
Yeast and Mold	SM 9610	x		Odor	SM2150B	x	
1,2,3-Trichloropropane (TCP) at 5 PPT	CA SRL 524M-TCP	x		Organohalide Pesticides and PCB	EPA 505	x	
1,4-Dioxane	EPA 522	x		Ortho Phosphate	SM 4500P E	x	
2,3,7,8-TCDD	Modified EPA 1613 B	x		Oxyhalides Disinfection Byproducts	EPA 317.0	x	
Acrylamide	+ LCMS 2440)	x		Perchlorate	EPA 331.0	x	
Algal Toxins/Microcystin	+ LCMS 3570	x		Perchlorate (Low and High Levels)	EPA 314.0	x	
Alkalinity	SM 2320B	x	x	Perfluorinated Alkyl Acids	EPA 533, EPA 537, EPA 537.1	x	
Ammonia	EPA 350.1, SM 4500-NH3 H		x	PPCP and EDC	+ LCMS-2443	x	
Asbestos	EPA 100.2	x	x	pH	EPA 150.1 SM 4500-H+ B	x	x
Bicarbonate Alkalinity as HCO3	SM 2330 B	x	x	Phenolics – Low Level	+WC 2493 (EPA 420.2 and EPA 420.4 MOD)	x	x
BOD/CBOD	SM 5210 B		x	Phenylurea Pesticides/Herbicides	+ LCMS-2448	x	
Bromate	+ LCMS- 2447	x		Radium-226, Radium-228	GA Tech (Rad-2374)	x	
Carbonate as CO3	SM 2330 B	x	x	Radon-222	SM 7500RN	x	
Carbonyls	EPA 556	x	x	Residue (Filterable)	SM 2540C	x	x
Chemical Oxygen Demand	EPA 410.4, SM 5220D		x	Residue (Non-Filterable)	SM 2540D		x
Chlorinated Acids	EPA 515.4	x		Residue (Total)	SM 2540B		x
Chlorine Dioxide	Palin Test Chlordio X Plus, SM 4500-CLO2 D	x		Residue (Volatile)	EPA 160.4		x
Chlorine, Free, Combined, Total Residual, Chloramines	SM 4500-Cl G	x		Semi-Volatile Compounds	EPA 525.2	x	
Color	SM2120B	x		Silica	SM 4500-SiO2 C	x	x
Conductivity	EPA 120.1, SM 2510B	x	x	Sulfide	SM 4500-S D		x
Corrosivity (Langelier Index), Carbonate as CO3, Hydroxide as OH Calculated	SM 2330 B	x		Sulfite	SM 4500-SO3 B	x	x
Cyanide (Amenable)	SM 4500-CN G	x	x	Surfactants	SM 5540C	x	x
Cyanide (Free)	SM 4500CN F	x	x	Taste and Odor	SM 6040 E	x	
Cyanide (Total)	EPA 335.4	x	x	Total Organic Carbon	SM 5310 C	x	x
Cyanogen Chloride (Screen)	+ 335 Mod (WC-24467)	x		Total Phenols	EPA 420.1		x
Diquat and Paraquat	EPA 549.2	x		Total Phenols	EPA 420.4	x	x
DBP and HAA	SM 6251 B	x		Triazine Pesticides and their Degradates	+ LCMS-3617	x	
Dissolved Organic Carbon	SM 5310 C	x		Turbidity	EPA 180.1	x	x
Dissolved Oxygen	SM 4500-O G		x	Uranium by ICP/MS	EPA 200.8	x	
EDB/DCBP/TCP	EPA 504.1	x		UV 254 Organic Constituents	SM 5910B	x	
EDB/DBCP and Disinfection Byproducts	EPA 551.1	x		VOCs	EPA 524.2	x	
EDTA and NTA	+ WC-2454	x		VOCs	+ (GCMS 2412) by EPA 524.2 modified	x	
Endothall	EPA 548.1, +(LCMS-2445)	x					
Fluoride	SM 4500F C	x	x				
Glyphosate	EPA 547	x					
Glyphosate and AMPA	+ LCMS-3618	x					
Gross Alpha and Gross Beta	EPA 900.0	x	x				

(*) includes: Bottled Water, Drinking Water and Water as Component of Food & Beverage.

(+) In-House Method

Acknowledgement of Samples Received

Addr: **Honolulu Board of Water Supply**
 630 South Beretania Street
 Public Service Bldg." Room 308
 Honolulu, HI 96843

Attn: Erwin Kawata
 Phone: 808-748-5091

Client ID: HONOLULU
 Folder #: 982678
 Project: RED-HILL
 Sample Group: Red-Hill Expanded List
 (Albuquerque+)
 Project Manager: Debbie L Frank
 Phone: (626) 386-1149
 PO #: C20525101 exp 05312023

The following samples were received from you on **January 25, 2022** at **1139**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
<u>202201250198</u>	AIEA WELLS PUMP 2 (HI0000331-004-TP072)	01/24/2022 1010
	(SUB)Gas Fraction Hydrocarbons TPH 8015 Diesel and Motor Oil TPH 8015 Jet Fuel 5 TPH 8015 Jef Fuel 8	
<u>202201250200</u>	Travel Blank	01/24/2022 1010
	(SUB)Gas Fraction Hydrocarbons	

Test Description

Kit Order for Honolulu Board of Water Supply

Debbie L Frank is your Eurofins Eaton Analytical, LLC Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Created Date & Time 12/10/2021 7:10:51PM

Note: Sampler Please return this paper with your samples

Kit #: 307672
Created By: - [AutoGenerated]
Deliver By: 12/22/2021
STG: Bottle Orders
Ice Type: G
Pre Registered

Client ID: HONOLULU
Project Code: RED-HILL Bottle Orders
Group Name: Red-Hill Expanded List (Albuquerque+)
PO#/JOB#: C20525101 exp 05312023
Description: AIEA WELLS PUMPS 1&2 (260) - Evei

Ship Sample Kits to
Honolulu Board of Water Supply
630 South Beretania Street
Chemistry Lab
Honolulu, HI 96843
Attn: Ron Fenstermacher
Phone: 808-748-5841
Fax: 808-550-5572

Send Report to
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg. Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808 748-5091
Fax: 808 550-5018

Billing Address
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg. Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808-748-5091
Fax: 808-550-5018

# of Sample	Tests	Bottle Qty - Type [preservative information]	Total	UN DOT #
1	@625A_Physis-G, @625BN_Physis-G, @625PAH_Physis_TICS_C	4 - 1L amber glass [1 ml Thio 8%]	4	
1	TPH 8015 Diesel and Motor Oil_C, TPH 8015 Jet Fuel 5_C, TPH 8015 Jet Fuel 8_C	4 - 1L amber glass [1 ml Thio 8%]	6	
1	8015 Gas_C	3 - 40ml amber glass vial [1 drop Thio (8%)]	3	
1	8015 Gas_C TB	2 - 40ml amber glass vial [1 drop Thio (8%) + H2O]	2	
1	@VOASDWA C plus plus TICs TB	3 - 40ml amber glass vial [25mg-AA+H2O+10 drop 1.1 HCL]	3	UN1789
1	@VOASDWA C plus plus TICs C	3 - 40ml amber glass vial [25mg-Ascorbic+drop-2ml 1.1 HCL]	3	UN1789
1	@8015_Ethanol_Subbed	3 - 40ml amber glass vial [no preservative]	3	
Sum Tests: 7			Sum Bottles: 24	

Comments

AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)
SAMPLER
Four 1 LITER AMBER GLASS BOTTLES FOR 625 SERIES AND Six 1 LITER AMBER GLASS BOTTLES FOR TPH 8015 SERIES
SHIPPING
Travel Blanks - TBAJMTBE, VOASDWA - Prepare TBs in the VOA LAB
Label Cooler on TOP and right below both Handles with Site description of contents (use extra Container Labels)
ASM Be sure to coordinate Follow-up as needed for any new detections in Field samples
Acetone - follow-ups need to use EPA 624



Eurofins Analytical

INTERNAL CHAIN OF CUSTODY RECORD

IEA Folder Number:

982678

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes (No)

IR Gun ID = 630 (Observation = 4.0 °C) (Corr.Factor = -0.2 °C) (Final = 3.8 °C)

TYPE OF ICE: Real Synthetic No Ice Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In / (FedEx) UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrant

1 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)

- 4) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)
- 5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date: _____ Results: _____
- 6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

VOA and Radon Headspace:		No Samples with Headspace:		Samples with Headspace (see below):				
Samp ID	Bottle #	None/<6	>6mm	Samp ID	Bottle #	None/<6	>6mm	Test

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors):

RECEIVED BY: <u>[Signature]</u>	SIGNATURE	FRONT NAME	COMPANY/TITLE	DATE	TIME
			Eurofins Eaton Analytical	1.25.22	1139
SAMPLES CHECKED AGAINST COO BY: <u>[Signature]</u>	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
			Eurofins Eaton Analytical		

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Comments

Report: 982678
Project: RED-HILL
Group: Red-Hill Expanded List
(Albuquerque+)

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Folder Comments

Results for TPH Gas, Diesel, Motor Oil and Jet Fuels are submitted by EMAX Laboratories

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 982678
Project: RED-HILL
Group: Red-Hill Expanded List
(Albuquerque+)

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Samples Received on:
01/25/2022 1139

Analyzed	Analyte	Sample ID	Result	HI Limit	Units	MRL
----------	---------	-----------	--------	----------	-------	-----

Tel: (626) 386-1100
 Fax: (626) 988-3757
 1 800 566 LABS (1 800 566 5227)

Report: 982678
Project: RED-HILL
Group: Red-Hill Expanded List
 (Albuquerque+)

Honolulu Board of Water Supply
 Erwin Kawata
 630 South Beretania Street
 Public Service Bldg." Room 308
 Honolulu, HI 96843

Samples Received on:
 01/25/2022 1139

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<u>AIEA WELLS PUMP 2 (HI0000331-004) (202201250198)</u>						Sampled on 01/24/2022 1010			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/26/22	01/26/22 17:31			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1
SW 8015B - TPH 8015 Diesel and Motor Oil									
01/27/22	01/28/22 16:02			(SW 8015B)	TPH Diesel	ND	mg/L	0.028	1
01/27/22	01/28/22 16:02			(SW 8015B)	TPH Motor Oil	ND	mg/L	0.055	1
EPA 8015 - Jet Fuel 5 C8-C18									
01/27/22	01/28/22 16:02			(EPA 8015)	Jet Fuel 5	ND	mg/L	0.055	1
EPA 8015 - Jet Fuel 8 C8-C18									
	01/28/22 16:02			(EPA 8015)	Jet Fuel 8	ND	mg/L	0.055	1
<u>Travel Blank (202201250200)</u>						Sampled on 01/24/2022 1010			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/26/22	01/26/22 19:21			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1

Rounding on totals after summation.
 (c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.



3051 Fujita Street
Torrance, CA 90505
Tel: (310)-618-8889

Date: 02-10-2022
EMAX Batch No.: 22A249

Attn: Jackie Contreras

Eurofins Eaton Analytical
750 Royal Oaks Dr., Suite 100
Monrovia, CA 91016-3629

Subject: Laboratory Report
Project: 982678

Enclosed is the Laboratory report for samples received on 01/26/22.
The data reported relate only to samples listed below :

Sample ID	Control #	Col Date	Matrix	Analysis
202201250198	A249-01	01/24/22	WATER	TPH GASOLINE TPH
202201250200	A249-02	01/24/22	WATER	TPH GASOLINE
202201250198MS	A249-01M	01/24/22	WATER	TPH GASOLINE TPH DIESEL
202201250198MSD	A249-01S	01/24/22	WATER	TPH GASOLINE TPH DIESEL

The results are summarized on the following pages.

Please feel free to call if you have any questions concerning these results.

Sincerely yours,

Caspar J. Pang
Laboratory Director

This report is confidential and intended solely for the use of the individual or entity to whom it is addressed. This report shall not be reproduced except in full or without the written approval of EMAX.

EMAX certifies that results included in this report meets all TNI & DOD requirements unless noted in the Case Narrative.

NELAP Accredited Certificate Number CA002912021-19
ANAB Accredited DoD ELAP and ISO/IEC 17025 Certificate Number L2278 Testing
California ELAP Accredited Certificate Number 2672



Eaton Analytical

Ship To:
EMAX Laboratories, Inc.
3051 Fujita St.
Torrance, CA 90505

Phone: 310-618-8889 Fax: 310-618-0818

Folder #: 982678 Report Due: 01/28/2022

Sample ID 202201250198 ^① Client Sample ID for reference onl
AIEA WELLS PUMP 2 (HI0000331-004)

Sample type: Sample Event: Analysis Requested

Method	Prep Method	Analysis Requested
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons
SW 8015B	EPA 3550B	TPH 8015 Diesel and Motor Oil
EPA 8015	EPA 8015	Jet Fuel 5 C8-C18
EPA 8015		Jet Fuel 8 C8-C18

Sample ID 202201250200 ^② Client Sample ID for reference onl
Travel Blank

Sample type: Sample Event: Analysis Requested

Method	Prep Method	Analysis Requested
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons

Date: 1/26/2022

Submittal Form

22A249

*REPORTING REQUIREMENTS: Do Not Combine Reports with any other samples submitted under different Folder Numbers!
Report & Invoice must have the Folder # 982678 Job # 1000014

Report all quality control data according to Method. Include dates analyzed. Date extracted (if extracted) and Method reference on the report.
Results must have Complete data & QC with Approval Signature.

Reports: Jackie Contreras Sub-Contracting Administrator
 EMAIL TO: Eaton-MonroviaSubContract@eurofinset.com
 Eurofins Eaton Analytical, LLC 750 Royal Oaks Drive, Suite 100, Monrovia, CA 91016
 Phone (626) 386-1165 Fax (626) 386-1122
 Invoices to: Eurofins Eaton Analytical, LLC
 Accounts Payable 2425 New Holland Pike, Lancaster, PA 17605

Provide in each Report the
 Specified State Certification # and
 Exp Date for requested tests + matrix.
 Samples from: HAWAII

3 day rush

Sample ID	Sample Date & Time	Matrix	Clip Code	PWSID
202201250198	01/24/22	1010 DW		JLS

Sample ID	Sample Date & Time	Matrix	Clip Code	PWSID
202201250200	01/24/22	1010 DW		JLS

Relinquished by: *[Signature]* Date: 1/26/22 Time: 12:13
 Received by: *[Signature]* Date: 1/26/22 Time: 12:13
 Relinquished by: *[Signature]* Date: 1/26/22 Time: 12:13
 Received by: *[Signature]* Date: 1/26/22 Time: 12:13

NOTIFICATION REQUIRED IF RECEIVED OUTSIDE OF 0-6 CELSIUS

An Acknowledgement of Receipt is requested to attain Jackie Contreras

Temp: 1.1

Date: 1/26/22 Time: 12:13 MF 1/24/22

Page 1 of 2

Type of Delivery	Airbill / Tracking Number	ECN <u>22A249</u>
<input type="checkbox"/> Fedex <input type="checkbox"/> UPS <input type="checkbox"/> GSO <input type="checkbox"/> Others		Recipient <u>Alan Ramos</u>
<input type="checkbox"/> EMAX Courier <input checked="" type="checkbox"/> Client Delivery		Date <u>01/26/22</u> Time <u>12:13</u>

COC INSPECTION

<input checked="" type="checkbox"/> Client Name	<input type="checkbox"/> Client PM/FC	<input type="checkbox"/> Sampler Name	<input checked="" type="checkbox"/> Sampling Date/Time	<input checked="" type="checkbox"/> Sample ID	<input checked="" type="checkbox"/> Matrix
<input checked="" type="checkbox"/> Address	<input checked="" type="checkbox"/> Tel # / Fax #	<input type="checkbox"/> Courier Signature	<input checked="" type="checkbox"/> Analysis Required	<input type="checkbox"/> Preservative (if any)	<input checked="" type="checkbox"/> TAT
Safety Issues (if any)	<input type="checkbox"/> High concentrations expected	<input type="checkbox"/> From Superfund Site	<input type="checkbox"/> Rad screening required		

Note: _____

PACKAGING INSPECTION

Container	<input checked="" type="checkbox"/> Cooler	<input type="checkbox"/> Box	<input type="checkbox"/> Other
Condition	<input type="checkbox"/> Custody Seal	<input type="checkbox"/> Intact	<input type="checkbox"/> Damaged
Packaging	<input checked="" type="checkbox"/> Bubble Pack	<input type="checkbox"/> Styrofoam	<input type="checkbox"/> Popcorn
Temperatures (Cool, ≤6 °C but not frozen)	<input checked="" type="checkbox"/> Cooler 1 <u>1.1</u> °C	<input type="checkbox"/> Cooler 2 _____ °C	<input type="checkbox"/> Cooler 3 _____ °C
	<input type="checkbox"/> Cooler 6 _____ °C	<input type="checkbox"/> Cooler 7 _____ °C	<input type="checkbox"/> Cooler 8 _____ °C
Thermometer: <u>A - S/N 210191066 on 1/14/22</u>	<input checked="" type="checkbox"/> B - S/N <u>210271396</u>	<input type="checkbox"/> C - S/N <u>210271399</u>	<input type="checkbox"/> D - S/N _____

Comments: Temperature is out of range. PM was informed IMMEDIATELY.

Note: _____

DISCREPANCIES

LabSampleID	LabSampleContainerID	Code	ClientSample Label ID / Information	Corrective Action
1	4-7	D22		R8
<div style="position: absolute; top: 50%; left: 50%; transform: translate(-50%, -50%); opacity: 0.5; font-size: 2em;">/</div>				

1/26/22

1/27/22

pH holding time requirement for water samples is 15 mins. Water samples for pH analysis are received beyond 15 minutes from sampling time.

NOTES/OBSERVATIONS:

LEGEND:

- Code Description-Sample Management**
- D1 Analysis is not indicated in _____
 - D2 Analysis mismatch COC vs label
 - D3 Sample ID mismatch COC vs label
 - D4 Sample ID is not indicated in _____
 - D5 Container -[improper] [leaking] [broken]
 - D6 Date/Time is not indicated in _____
 - D7 Date/Time mismatch COC vs label
 - D8 Sample listed in COC is not received
 - D9 Sample received is not listed in COC
 - D10 No initial/date on corrections in COC/label
 - D11 Container count mismatch COC vs received
 - D12 Container size mismatch COC vs received

- Code Description-Sample Management**
- D13 Out of Holding Time
 - D14 Bubble is >6mm
 - D15 No trip blank in cooler
 - D16 Preservation not indicated in _____
 - D17 Preservation mismatch COC vs label
 - D18 Insufficient chemical preservative
 - D19 Insufficient Sample
 - D20 No filtration info for dissolved analysis
 - D21 No sample for moisture determination
 - D22 JET Fuel & Analysis not indicated on label
 - D23 _____
 - D24 _____

- Continue to next page.
- Code Description-Sample Management**
- R1 Proceed as indicated in COC Label
 - R2 Refer to attached instruction
 - R3 Cancel the analysis
 - R4 Use vial with smallest bubble first
 - R5 Log-in with latest sampling date and time+1 min
 - R6 Adjust pH as necessary
 - R7 Filter and preserved as necessary
 - R8 Informed client
 - R9 _____
 - R10 _____
 - R11 _____
 - R12 _____

REVIEWS:

Sample Labeling Maria Rivera
Date 01/26/22

SRF [Signature]
Date 1/26/22

PM [Signature]
Date 1/27/22

REPORTING CONVENTIONS

DATA QUALIFIERS:

Lab Qualifier	AFCEE Qualifier	Description
J	F	Indicates that the analyte is positively identified and the result is less than LOQ/RL but greater than LOD/MDL/DL.
N		Indicates presumptive evidence of a compound.
B	B	Indicates that the analyte is found in the associated method blank as well as in the sample at above QC level.
E	J	Indicates that the result is above the maximum calibration range or estimated value.
*	*	Out of QC limit.

Note: The above qualifiers are used to flag the results unless the project requires a different set of qualification criteria.

ACRONYMS AND ABBREVIATIONS:

CRDL	Contract Required Detection Limit
RL	Reporting Limit
MRL	Method Reporting Limit
MDL	Method Detection Limit
DL	Detection Limit
LOD	Limit of Detection
LOQ	Limit of Quantitation
DO	Diluted out

DATES

The date and time information for leaching and preparation reflect the beginning date and time of the procedure unless the method, protocol, or project specifically requires otherwise.

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

982678

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

SDG#: 22A249

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 982678

SDG : 22A249

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

A total of two(2) water samples were received on 01/26/22 to be analyzed for Total Petroleum Hydrocarbons by Purge and Trap in accordance with Method 5030B/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. VG39A16B - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. VG39A16L/VG39A16C were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Gasoline was within MS QC limits in A249-01M/A249-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogate was added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

SAMPLE RESULTS

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/24/22 10:10
Project     : 982678                      Date Received: 01/26/22
Batch No.   : 22A249                      Date Extracted: 01/26/22 17:31
Sample ID   : 202201250198              Date Analyzed: 01/26/22 17:31
Lab Samp ID: A249-01                    Dilution Factor: 1
Lab File ID: EA26009A                  Matrix: WATER
Ext Btch ID: 22VG39A16                % Moisture: NA
Calib. Ref.: EA26004A                  Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0342	0.0400	85	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/24/22 10:10
Project     : 982678                     Date Received: 01/26/22
Batch No.   : 22A249                     Date Extracted: 01/26/22 19:21
Sample ID   : 202201250200               Date Analyzed: 01/26/22 19:21
Lab Samp ID : A249-02                    Dilution Factor: 1
Lab File ID : EA26012A                   Matrix: WATER
Ext Btch ID : 22VG39A16                  % Moisture: NA
Calib. Ref.: EA26004A                    Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0343	0.0400	86	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

QC SUMMARIES

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/26/22 15:41
Project     : 982678                     Date Received: 01/26/22
Batch No.   : 22A249                     Date Extracted: 01/26/22 15:41
Sample ID   : MBLK1W                     Date Analyzed: 01/26/22 15:41
Lab Samp ID: VG39A16B                    Dilution Factor: 1
Lab File ID: EA26006A                    Matrix: WATER
Ext Btch ID: 22VG39A16                   % Moisture: NA
Calib. Ref.: EA26004A                    Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0347	0.0400	87	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 5030B/8015B

MATRIX : WATER		% MOISTURE:NA
DILUTION FACTOR: 1	1	1
SAMPLE ID : MBLK1W	LCS1W	LCD1W
LAB SAMPLE ID : VG39A16B	VG39A16L	VG39A16C
LAB FILE ID : EA26006A	EA26007A	EA26008A
DATE PREPARED : 01/26/22 15:41	01/26/22 16:18	01/26/22 16:54
DATE ANALYZED : 01/26/22 15:41	01/26/22 16:18	01/26/22 16:54
PREP BATCH : 22VG39A16	22VG39A16	22VG39A16
CALIBRATION REF: EA26004A	EA26004A	EA26004A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.461	92	0.500	0.467	93	1	60-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0438	110	0.0400	0.0431	108	70-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 5030B/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201250198                       202201250198MS
LAB SAMPLE ID : A249-01                          A249-01S
LAB FILE ID  : EA26009A                          EA26010A
DATE PREPARED : 01/26/22 17:31                   01/26/22 18:08
DATE ANALYZED : 01/26/22 17:31                   01/26/22 18:44
PREP BATCH   : 22VG39A16                         22VG39A16
CALIBRATION REF: EA26004A                       EA26004A
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.458	92	0.500	0.511	102	11	50-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0429	107	0.0400	0.0509	127	60-140

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

982678

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

SDG#: 22A249

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 982678

SDG : 22A249

METHOD 3520C/8015B TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/26/22 to be analyzed for Total Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA019WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. DSA019WL/DSA019WC were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Diesel was within MS QC limits in 22A249-01M/22A249-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 982678

SDG : 22A249

METHOD 3520C/8015B PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/26/22 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA019WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. J5A019WL/J5A019WC were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG. One(1) set of MS/MSD was analyzed. JP5 was within MS QC limits in 22A250-01M/22A250-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 982678

SDG : 22A249

METHOD 3520C/8015B PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/26/22 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA019WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. J8A019WL/J8A019WC were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project     : 982678
=====
SDG NO.    : 22A249
Instrument ID : D5
=====
    
```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	WATER		Extraction DateTime	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
				Analysis DateTime	Extraction DateTime					
MBLK1W	DSA019WB	1	NA	01/28/2213:54	01/27/2213:00	LA28010A	LA28005A	2BDSA019W	Method Blank	
LCS1W	J5A019WL	1	NA	01/28/2214:49	01/27/2213:00	LA28013A	LA28005A	2BDSA019W	Lab Control Sample (LCS)	
LCD1W	J5A019WC	1	NA	01/28/2215:07	01/27/2213:00	LA28014A	LA28005A	2BDSA019W	LCS Duplicate	
202201250198	A249-01	1	NA	01/28/2216:02	01/27/2213:00	LA28017A	LA28005A	2BDSA019W	Field Sample	

FN - Filename
 % Moist - Percent Moisture

SAMPLE RESULTS

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/24/22 10:10
Project     : 982678                      Date Received: 01/26/22
Batch No.   : 22A249                      Date Extracted: 01/27/22 13:00
Sample ID   : 202201250198               Date Analyzed: 01/28/22 16:02
Lab Samp ID : 22A249-01                   Dilution Factor: 1
Lab File ID : LA28017A                    Matrix: WATER
Ext Btch ID : 22DSA019W                   % Moisture: NA
Calib. Ref.: LA28005A                     Instrument ID: D5
=====
  
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.055	0.028

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.494	0.550	90	60-130
Hexacosane	0.126	0.138	92	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 910ml Final Volume : 5ml
 Prepared by : POrreto Analyzed by : SDeeso

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/24/22 10:10
Project     : 982678                     Date Received: 01/26/22
Batch No.   : 22A249                     Date Extracted: 01/27/22 13:00
Sample ID   : 202201250198              Date Analyzed: 01/28/22 16:02
Lab Samp ID: 22A249-01                   Dilution Factor: 1
Lab File ID: LA28017A                    Matrix: WATER
Ext Btch ID: 22DSA019W                   % Moisture: NA
Calib. Ref.: LA28006A                    Instrument ID: D5
=====
  
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JPB	ND	0.055	0.028

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.494	0.550	90	60-130
Hexacosane	0.126	0.138	92	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JPB C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 910ml Final Volume : 5ml
 Prepared by : P0reto Analyzed by : SDeeso

QC SUMMARIES

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/27/22 13:00
Project     : 982678                     Date Received: 01/27/22
Batch No.   : 22A249                     Date Extracted: 01/27/22 13:00
Sample ID   : MBLK1W                     Date Analyzed: 01/28/22 13:54
Lab Samp ID: DSA019WB                    Dilution Factor: 1
Lab File ID: LA28010A                    Matrix: WATER
Ext Btch ID: 22DSA019W                    % Moisture: NA
Calib. Ref.: LA28004A                    Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
Diesel	ND	0.025	0.012
Motor Oil	ND	0.050	0.025

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.397	0.500	79	60-130
Hexacosane	0.105	0.125	84	60-130

Notes:

Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml Final Volume : 5ml
Prepared by : POrto Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 3520C/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : MBLK1W                             LCS1W         LCD1W
LAB SAMPLE ID : DSA019WB                         DSA019WL     DSA019WC
LAB FILE ID  : LA28010A                         LA28011A     LA28012A
DATE PREPARED : 01/27/22 13:00                 01/27/22 13:00
DATE ANALYZED : 01/28/22 13:54                 01/28/22 14:12
PREP BATCH   : 22DSA019W                       22DSA019W    22DSA019W
CALIBRATION REF: LA28004A                     LA28004A     LA28004A
  
```

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Diesel	ND	2.50	2.23	89	2.50	2.00	80	11	50-130	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromobenzene	0.500	0.478	96	0.500	0.381	76	60-130
Hexacosane	0.125	0.116	93	0.125	0.109	87	60-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 3520C/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201250198                       202201250198MSD
LAB SAMPLE ID : 22A249-01                         22A249-01S
LAB FILE ID  : LA28017A                           LA28019A
DATE PREPARED : 01/27/22 13:00                   01/27/22 13:00
DATE ANALYZED : 01/28/22 16:02                   01/28/22 16:39
PREP BATCH   : 22DSA019W                           22DSA019W
CALIBRATION REF: LA28004A                         LA28004A
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Diesel	ND	2.62	2.17	83	2.65	2.50	94	14	50-130	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.525	0.438	83	0.530	0.537	101	60-130
Hexacosane	0.131	0.118	90	0.132	0.132	100	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/27/22 13:00
Project     : 982678                     Date Received: 01/27/22
Batch No.   : 22A249                     Date Extracted: 01/27/22 13:00
Sample ID   : MBLK1W                     Date Analyzed: 01/28/22 13:54
Lab Samp ID : DSA019WB                   Dilution Factor: 1
Lab File ID : LA28010A                   Matrix: WATER
Ext Btch ID: 22DSA019W                   % Moisture: NA
Calib. Ref.: LA28005A                   Instrument ID: D5
=====
    
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.050	0.025

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.397	0.500	79	60-130
Hexacosane	0.105	0.125	84	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
 Sample Amount : 1000ml Final Volume : 5ml
 Prepared by : POrto Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 3520C/8015B

MATRIX	: WATER		% MOISTURE:NA
DILUTION FACTOR:	1	1	1
SAMPLE ID	: MBLK1W	LCS1W	LCD1W
LAB SAMPLE ID	: DSA019WB	J5A019WL	J5A019WC
LAB FILE ID	: LA28010A	LA28013A	LA28014A
DATE PREPARED	: 01/27/22 13:00	01/27/22 13:00	01/27/22 13:00
DATE ANALYZED	: 01/28/22 13:54	01/28/22 14:49	01/28/22 15:07
PREP BATCH	: 22DSA019W	22DSA019W	22DSA019W
CALIBRATION REF:	LA28005A	LA28005A	LA28005A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JP5	ND	2.50	2.49	100	2.50	2.82	113	12	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromobenzene	0.500	0.446	89	0.500	0.482	96	60-130
Hexacosane	0.125	0.103	82	0.125	0.115	92	60-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982686
BATCH NO. : 22A250
METHOD : 3520C/8015B

MATRIX	: WATER		% MOISTURE:NA
DILUTION FACTOR:	1	1	1
SAMPLE ID	: 202201250220	202201250220MS	202201250220MSD
LAB SAMPLE ID	: 22A250-01	22A250-01M	22A250-01S
LAB FILE ID	: LA28020A	LA28021A	LA28022A
DATE PREPARED	: 01/27/22 13:00	01/27/22 13:00	01/27/22 13:00
DATE ANALYZED	: 01/28/22 16:58	01/28/22 17:16	01/28/22 17:34
PREP BATCH	: 22DSA019W	22DSA019W	22DSA019W
CALIBRATION REF:	LA28005A	LA28005A	LA28005A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JP5	ND	2.53	2.92	116	2.53	2.76	109	6	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.505	0.466	92	0.505	0.441	87	60-130
Hexacosane	0.126	0.109	86	0.126	0.110	87	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/27/22 13:00
Project     : 982678                     Date Received: 01/27/22
Batch No.   : 22A249                     Date Extracted: 01/27/22 13:00
Sample ID   : MBLK1W                     Date Analyzed: 01/28/22 13:54
Lab Samp ID: DSA019WB                   Dilution Factor: 1
Lab File ID: LA28010A                   Matrix: WATER
Ext Btch ID: 22DSA019W                   % Moisture: NA
Calib. Ref.: LA28006A                   Instrument ID: D5
=====
    
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP8	ND	0.050	0.025

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.397	0.500	79	60-130
Hexacosane	0.105	0.125	84	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP8 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml Final Volume : 5ml
 Prepared by : POrreto Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 982678
BATCH NO. : 22A249
METHOD : 3520C/8015B

```

=====
MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1 1
SAMPLE ID : MBLK1W LCS1W LCD1W
LAB SAMPLE ID : DSA019WB J8A019WL J8A019WC
LAB FILE ID : LA28010A LA28015A LA28016A
DATE PREPARED : 01/27/22 13:00 01/27/22 13:00 01/27/22 13:00
DATE ANALYZED : 01/28/22 13:54 01/28/22 15:25 01/28/22 15:44
PREP BATCH : 22DSA019W 22DSA019W 22DSA019W
CALIBRATION REF: LA28006A LA28006A LA28006A
  
```

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JPB	ND	2.50	2.73	109	2.50	2.62	105	4	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromobenzene	0.500	0.537	107	0.500	0.529	106	60-130
Hexacosane	0.125	0.120	96	0.125	0.116	93	60-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate