


750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Report

for

Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843
Attention: Erwin Kawata
Fax: 808-550-5018



Utah ELCP CA00006

DEB: Debbie L Frank
Project Manager

Report: 1000367
Project: RED-HILL
Group: Weekly TPH-8015_RED-HILL (2022) - EMAX

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis.

* As applicable, this report consists of the cover page, State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	NE-OS-21-13
Arkansas	CA00006	Nevada	CA00006
California	2813	New Hampshire *	2959
Colorado	CA00006	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	CA00006
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	21-008R	Ohio - 537.1	87786
Hawaii	CA00006	Oregon *	4034
Idaho	CA00006	Pennsylvania *	68-00565
Illinois	200033	Puerto Rico	CA00006
Indiana	C-CA-01	Rhode Island	LAO00326
Iowa – Asbestos	413	South Carolina	87016
Kansas *	E-10268	South Dakota	CA11320
Kentucky	90107	Tennessee	TN02839
Louisiana *	LA008	Texas *	T104704230-20-18
Maine	CA00006	Utah (Primary AB) *	CA00006
Maryland	224	Vermont	VT0114
Marianas Islands	MP0004	Virginia *	460260
Massachusetts	M-CA006	Washington	C838
Michigan	9906	EPA Region 5	CA00006
Mississippi	CA00006	Los Angeles County Sanitation Districts	10264

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025:2017 Accredited Method List

The test listed below are accredited and met the requirements of ISO/IEC 17025 as verify by A2LA.

Refer to our certificates and scope of accreditations (no. 5890-1 and 5890-2) found at:

<https://www.eurofinsus.com/Eaton>

Test(s)	Method(s)	Potable Water *	Waste Water
Enterococci	Enterolert	x	x
Escherichia coli (Enumeration)	SM 9221 B.1 SM 9221 F	x	
Fecal Coliform (P/A and Enumeration)	SM 9221 C (MTF/EC), SM 9221 E (MTF/EC)	x	x
Fecal Streptococci and Enterococci	SM 9230 B	x	x
Heterotrophic Bacteria	SM 9215 B	x	
Legionella	Legiolert®	x	
Pseudomonas aeruginosa	Idexx Pseudalert	x	
Total Coliform (P/A and Enumeration)	SM 9221A, SM 9221B, SM 9221 C	x	x
Total Coliform, Total Coliform with Chlorine Present	SM 9221 B	x	x
Total Coliform/E. coli (P/A and Enumeration, Idexx Colilert, Idexx Colilert 18, Colisure)	SM 9223	x	
Total Microcystins and Nodularins	EPA 546	X	
Yeast and Mold	SM 9610	x	
1,2,3-Trichloropropane (TCP) at 5 PPT	CA SRL 524M-TCP	x	
1,4-Dioxane	EPA 522	x	
2,3,7,8-TCDD	Modified EPA 1613 B	x	
Acrylamide	+ LCMS 2440)	x	
Algal Toxins/Microcys in	+ LCMS 3570	x	
Alkalinity	SM 2320B	x	x
Ammonia	EPA 350.1, SM 4500-NH3 H		x
Asbestos	EPA 100.2	x	x
Bicarbonate Alkalinity as HCO3	SM 2330 B	x	x
BOD/CBOD	SM 5210 B		x
Bromate	+ LCMS- 2447	x	
Carbonate as CO3	SM 2330 B	x	x
Carbonyls	EPA 556	x	x
Chemical Oxygen Demand	EPA 410.4, SM 5220D		x
Chlorinated Acids	EPA 515.4	x	
Chlorine Dioxide	Palin Test Chlordio X Plus, SM 4500-CLO2 D	x	
Chlorine, Free, Combined, Total Residual, Chloramines	SM 4500-Cl G	x	
Color	SM2120B	x	
Conductivity	EPA 120.1, SM 2510B	x	x
Corrosivity (Langelier Index), Carbonate as CO3, Hydroxide as OH Calculated	SM 2330 B	x	
Cyanide (Amenable)	SM 4500-CN G	x	x
Cyanide (Free)	SM 4500CN F	x	x
Cyanide (Total)	EPA 335.4	x	x
Cyanogen Chloride (Screen)	+ 335 Mod (WC-24467)	x	
Diquat and Paraquat	EPA 549.2	x	
DBP and HAA	SM 6251 B	x	
Dissolved Organic Carbon	SM 5310 C	x	
Dissolved Oxygen	SM 4500-O G		x
EDB/DCBP/TCP	EPA 504.1	x	
EDB/DBCP and Disinfection Byproducts	EPA 551.1	x	
EDTA and NTA	+ WC-2454	x	
Endothall	EPA 548.1, +(LCMS-2445)	x	
Fluoride	SM 4500F C	x	x
Glyphosate	EPA 547	x	
Glyphosate and AMPA	+ LCMS-3618	x	
Gross Alpha and Gross Beta	EPA 900.0	x	x

Test(s)	Method(s)	Potable Water *	Waste Water
Gross Alpha coprecipitation	SM 7110 C	x	x
Hardness	SM 2340 B	x	x
Hexavalent Chromium	EPA 218.6,	x	x
Hexavalent Chromium	EPA 218.7,	x	
Hexavalent Chromium	SM 3500-Cr B		x
Inorganic Anions and DBPs	EPA 300.0	x	x
Norganic Anions and DBPs	EPA 300.1	x	
Kjeldahl Nitrogen	EPA 351.2		x
Metals	EPA 200.7, EPA200.8	x	x
Nitrosamines	EEA-Agilent 521.1 (GCMS-24250)	x	
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x
Odor	SM2150B	x	
Organohalide Pesticides and PCB	EPA 505	x	
Ortho Phosphate	SM 4500P E	x	
Oxyhalides Disinfect ion Byproducts	EPA 317.0	x	
Perchlorate	EPA 331.0	x	
Perchlorate (Low and High Levels)	EPA 314.0	x	
Perfluorinated Alkyl Acids	EPA 533, EPA 537, EPA 537.1	x	
PPCP and EDC	+ LCMS-2443	x	
pH	EPA 150.1 SM 4500-H+ B	x	x
Phenolics – Low Level	+WC 2493 (EPA 420.2 and EPA 420.4 MOD)	x	x
Phenylurea Pesticides/Herbicides	+ LCMS-2448	x	
Radium-226, Radium-228	GA Tech (Rad-2374)	x	
Radon-222	SM 7500RN	x	
Residue (Filterable)	SM 2540C	x	x
Residue (Non-Filterable)	SM 2540D		x
Residue (Total)	SM 2540B		x
Residue (Volatile)	EPA 160.4		x
Semi-Volatile Compounds	EPA 525.2	x	
Silica	SM 4500-SiO2 C	x	x
Sulfide	SM 4500-S D		x
Sulfite	SM 4500-SO3 B	x	x
Surfactants	SM 5540C	x	x
Taste and Odor	SM 6040 E	x	
Total Organic Carbon	SM 5310 C	x	x
Total Phenols	EPA 420.1		x
Total Phenols	EPA 420.4	x	x
Triazine Pesticides and their Degradates	+ LCMS-3617	x	
Turbidity	EPA 180.1	x	x
Uranium by ICP/MS	EPA 200.8	x	
UV 254 Organic Constituents	SM 5910B	x	
VOCs	EPA 524.2	x	
VOCs	+(GCMS 2412) by EPA 524.2 modified	x	

(*) includes: Bottled Water, Drinking Water and Water as Component of Food & Beverage.

(+) In-House Method

Acknowledgement of Samples Received

Addr: **Honolulu Board of Water Supply**
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Attn: Erwin Kawata
Phone: 808-748-5091

Client ID: HONOLULU
Folder #: 1000367
Project: RED-HILL
Sample Group: Weekly TPH-8015_RED-HILL (2022)
- EMAX
Project Manager: Debbie L Frank
Phone: (626) 386-1149
PO #: C20525101 exp 05312023

The following samples were received from you on **April 20, 2022 at 1501**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
<u>202204200839</u>	AIEA WELLS P2 (260)-331-004-WL103	04/18/2022 1017
	(SUB)Gas Fraction Hydrocarbons TPH 8015 Diesel and Motor Oil	
<u>202204200840</u>	TB: AIEA WELLS P2 (260)-331-004-WL103	04/18/2022 1017
	(UB)Gas Fraction Hydrocarbons	

Test Description

CHAIN OF CUSTODY RECORD

EUROFINS EATON ANALYTICAL USE ONLY.

750 Royal Oaks Drive, Suite 100
 Monrovia, CA 91016-3629
 Phone: 626 386 1100
 Fax: 626 386 1101
 800 566 LABS (800 566 5227)

LOGIN COMMENTS:

SAMPLE TEMP RECEIVED AT:

Colton / No. California / Arizona
 Monrovia

37 °C (Compliance: 4 ± 2 °C)
 Partially Frozen / Thawed

CONDITION OF BLUE ICE: Frozen Thawed Wet Ice No Ice

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: FedEx

SAMPLES CHECKED AGAINST COC BY: GR

SAMPLES LOGGED IN BY: GR

SAMPLES REC'D DAY OF COLLECTION? (check for yes)

TO BE COMPLETED BY SAMPLER:

COMPANY/AGENCY NAME: BWS HONOLULU		PROJECT CODE: RED HILL	COMPLIANCE SAMPLES <input type="checkbox"/> - Requires state forms	NON-COMPLIANCE SAMPLES <input checked="" type="checkbox"/>
EEA CLIENT CODE:	COC ID:	SAMPLE GROUP:	Type of samples (circle one):	REGULATION INVOLVED:
			ROUTINE <input type="checkbox"/> SPECIAL <input type="checkbox"/> CONFIRMATION (eg. SDWA, Phase V, NPDES, FDA, ...)	

SEE ATTACHED BOTTLE ORDER FOR ANALYSES (check for yes), OR list ANALYSES REQUIRED (enter number of bottles sent for each test for each sample)

SAMPLE DATE	SAMPLE TIME	SAMPLE ID	CLIENT LAB ID	MATRIX	FIELD DATA	STD		FIELD DATA	SAMPLER COMMENTS
						1 wk	3 day		
04/18/22	107	Aiea Wells Pump P2	HI0000331-004	CFW					Temp Blank: _____ °C

* MATRIX TYPES: RSW = Raw Surface Water, RGW = Raw Ground Water, CFW = Chlor(am)inated Finished Water, WW = Waste Water, SEAW = Sea Water, BW = Bottled Water, SO = Soil, FW = Other Finished Water, SW = Storm Water, SL = Sludge

SAMPLED BY:	[REDACTED]	PRINT NAME	L. Bailey	COMPANY/TITLE	Honolulu Board of Water Supply	DATE	April 18, 2022	TIME	
RELINQUISHED BY:	[REDACTED]		L. Bailey		Honolulu Board of Water Supply		4/19/2022		1200
RECEIVED BY:	[REDACTED]		G. PEUTNER		SEA		04/20/2022		15:01
RELINQUISHED BY:									
RECEIVED BY:									



INTERNAL CHAIN OF CUSTODY RECORD

Eaton Analytical

EEA Folder Number: 110267

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 649A (Observation = 4.0 °C) (Corr. Factor = 0.3 °C) (Final = 3.7 °C)
TYPE OF ICE: Real Synthetic No Ice Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

- 4) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)
- 5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____
- 6) Chlorine check. Manufacturer: Samsafe. Lot No.: _____ Expiration Date: _____ Results _____

VOA and Radon Headspace: No Samples with Headspace: Samples with Headspace (see below):

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(6251,552), 505, SPME, @CH, 532LCMS, 556, 536, Anatoxin, LCMS methods using 40 ml vials, international clients:


Samp ID	Bottle #	None/<6	>6mm	Test	Samp ID	Bottle #	None/<6	>6mm	Test

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY: [Signature] SIGNATURE: G. REITNER PRINT NAME: _____

COMPANY/TITLE: Eurofins Eaton Analytical DATE: 04/20/2022 TIME: 15:01

SAMPLES CHECKED AGAINST COC BY: _____ SIGNATURE: _____ PRINT NAME: Eurofins Eaton Analytical DATE: _____ TIME: _____



INTERNAL CHAIN OF CUSTODY RECORD

Eaton Analytical

EEA Folder Number:

SAMPLE TEMP RECEIVED:
Note: If samples are out of temperature range, list the ASMs know. ASMs will determine whether to proceed with analysis or not.
SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 649A (Observation = 5.2 °C) (Corr.Factor = 0.3 °C) (Final = 4.9 °C)
TYPE OF ICE: Real Synthetic No Ice Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-in / FedEx / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)


4 Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)
5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____
6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

Samp ID	Bottle #	Nonal/<6	>8mm	Test	Samp ID	Bottle #	Nonal/<6	>8mm	Test	Samp ID	Bottle #	Nonal/<6	>8mm	Test

VOA and Radon No Samples with Headspace: Samples with Headspace (see below):
7) Headspace: Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)
Exempt from headspace concerns: Methods 615.4, HAA(6251,652), 605, 8PME, @CH, 632LCMS, 556, 538, AnatoxIn, LCMS methods using 40 ml vials, International clients: _____

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
	G. PEITNER	Eurofins Eaton Analytical	01-20-2022	15:01
SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
		Eurofins Eaton Analytical		



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 649A (Observation = 4.4 °C) (Corr.Factor = 0.3 °C) (Final = 4.1 °C)

TYPE OF ICE: Real Synthetic No Ice Frozen Partially Frozen Thawed N/A

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEX / UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2, hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)

4 DioxIn (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date _____ Results: _____

6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace: No Samples with Headspace: Samples with Headspace (see below):

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 616.4, HAA(6251,552), 506, SPME, @CH, 522LCMS, 566, 636, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	None/≤6	>6mm	Test	Samp ID	Bottle #	None/≤6	>6mm	Test

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

SIGNATURE 	PRINT NAME G. P. RITNER	COMPANY/TITLE Eurolins Eaton Analytical	DATE 04-20-2022	TIME 15:01
SIGNATURE	PRINT NAME	COMPANY/TITLE Eurolins Eaton Analytical	DATE	TIME

ORIGIN ID:HIKA (808) 748-5840
BWS CHEM LAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST.
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE: 19APR22
ACTWGT: 48.00 LB
CAD: 100205419/NET4460


BILL RECIPIENT

EUROFINS EATON ANALYTICAL, INC
750 ROYAL OAKS DR
SUITE 100

MONROVIA CA 91016
REF: (626) 386-1178

56DJ2BD9F9/FE4A


PO: INV. PC: DEPT:



WED - 20 APR 10:30A
PRIORITY OVERNIGHT

1 of 3
TRK# 7766 2340 8150
0201
MASTER

WZ WHPA
91016
CA-US BUR



After printing this label:
1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our Service Guide. Written claims must be filed within strict time limits, see current FedEx Service Guide.


ORIGIN ID:HIKA (808) 748-5840
BWS CHEM LAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST.
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE: 19APR22
ACTWGT: 48.00 LB
CAD: 100205419/NET4460
BILL RECIPIENT

TO
EUROFINS EATON ANALYTICAL, INC
750 ROYAL OAKS DR
SUITE 100
MONROVIA CA 91016

INV# (626) 386-1178
PO. DEPT:

56DJ2BD9F9FE4A




WED - 20 APR 10:30A
PRIORITY OVERNIGHT

MPS# 7766 2340 9640
Mstr# 7766 2340 8150

0263

91016
BUR
CA-US

WZ WHPA



After printing this label:
1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.
Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.
Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.


ORIGIN ID:HIKA (809) 748-5840
 BMS-CHEM-LAB
 HONOLULU BOARD OF WATER SUPPLY
 630 S. BERETANIA ST.
 CHEMICAL LABORATORY
 HONOLULU HI 96843
 UNITED STATES US

SHIP DATE: 19APR22
 ACTWGT: 48.00 LB
 CAD: 100205419/NET14460

BILL RECIPIENT

TO
 EUROFINS EATON ANALYTICAL, INC
 750 ROYAL OAKS DR
 SUITE 100
 MONROVIA CA 91016
 (626) 386-1178 REF:
 INV:
 PO: DEPT:

56D.J2/BDF9/FE4A




3 of 3

WED - 20 APR 10:30A
 PRIORITY OVERNIGHT

MPS# 7766 2341 0676
 0263
 Mst# 7766 2340 8150

91016
 CAUS BUR

WZ WHPA



After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.
 Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Comments

Report: 1000367
Project: RED-HILL
Group: Weekly TPH-8015_RED-HILL (2022)
- EMAX

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Folder Comments

Results for Gas, Diesel and Motor Oil are submitted by Emax Laboratories



Eaton Analytical

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Hits

Report: 1000367
Project: RED-HILL
Group: Weekly TPH-8015_RED-HILL (2022)
- EMAX

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Samples Received on:
04/20/2022 1501

Analyzed	Analyte	Sample ID	Result	HI Limit	Units	MRL
----------	---------	-----------	--------	----------	-------	-----

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
 Fax: (626) 988-3757
 1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 1000367
Project: RED-HILL
Group: Weekly TPH-8015_RED-HILL (2022)
 - EMAX

Honolulu Board of Water Supply
 Erwin Kawata
 630 South Beretania Street
 Public Service Bldg." Room 308
 Honolulu, HI 96843

Samples Received on:
 04/20/2022 1501

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<u>AIEA WELLS P2 (260)-331-004-WL103 (202204200839)</u>						Sampled on 04/18/2022 1017			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
04/22/22	04/22/22 14:04			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1
SW 8015B - TPH 8015 Diesel and Motor Oil									
04/25/22	04/27/22 15:11			(SW 8015B)	TPH Diesel	ND	mg/L	0.026	1
04/25/22	04/27/22 15:11			(SW 8015B)	TPH Motor Oil	ND	mg/L	0.052	1
<u>TB: AIEA WELLS P2 (260)-331-004-WL103 (202204200840)</u>						Sampled on 04/18/2022 1017			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
04/22/22	04/22/22 15:55			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1

Rounding on totals after summation.
 (c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.



3051 Fujita Street
Torrance, CA 90505
Tel: (310)-618-8889

Date: 04-29-2022
EMAX Batch No.: 22D210

Attn: Jackie Contreras

Eurofins Eaton Analytical
750 Royal Oaks Dr., Suite 100
Monrovia, CA 91016-3629

Subject: Laboratory Report
Project: 1000367

Enclosed is the Laboratory report for samples received on 04/21/22.
The data reported relate only to samples listed below :

Sample ID	Control #	Col Date	Matrix	Analysis
202204200839	D210-01	04/18/22	WATER	TPH GASOLINE TPH DIESEL & MOTOR OIL
202204200840	D210-02	04/18/22	WATER	TPH GASOLINE
202204200839MS	D210-01M	04/18/22	WATER	TPH GASOLINE TPH DIESEL & MOTOR OIL
202204200839MSD	D210-01S	04/18/22	WATER	TPH GASOLINE TPH DIESEL & MOTOR OIL

The results are summarized on the following pages.

Please feel free to call if you have any questions concerning these results.

Sincerely yours,

Caspar J. Pang
Laboratory Director

This report is confidential and intended solely for the use of the individual or entity to whom it is addressed. This report shall not be reproduced except in full or without the written approval of EMAX.

EMAX certifies that results included in this report meets all TNI & DOD requirements unless noted in the Case Narrative.

NELAP Accredited Certificate Number CA002912021-19
ANAB Accredited DoD ELAP and ISO/IEC 17025 Certificate Number L2278 Testing
California ELAP Accredited Certificate Number 2672



Eaton Analytical

Ship To:
EMAX Laboratories, Inc.
3051 Fujita St.
Torrance, CA 90505

Phone: 310-618-8888 Fax: 310-618-0818

Folder #: 1000367 Report Due: 04/27/2022

Submittal Form

Date: 4/21/2022

*REPORTING REQUIREMENTS: Do Not Combine Reports with any other samples submitted under different Folder Numbers!
Report & Invoice must have the Folder# 1000367 Job # 1000014

Report all quality control data according to Method. Include dates analyzed. Date extracted (if extracted) and Method reference on the report.
Results must have Complete data & QC with Approval Signature.

Reports: Jackie Contreras Sub-Contracting Administrator
EMAIL TO: Eaton-MonroviaSubContract@eurofins.com
Eurofins Eaton Analytical, LLC 750 Royal Oaks Drive, Suite 100, Monrovia, CA 91016
Phone (626) 386-1155 Fax (626) 386-1122
Invoices to: Eurofins Eaton Analytical, LLC
Accounts Payable 2425 New Holland Pike, Lancaster, PA 17605

Provide in each Report the
Specified State Certification # and
Exp. Date for requested tests + matrix.
Samples from: HAWAII

Sample ID 202204200839	Client Sample ID for reference on AIEA WELLS P2 (260)-331-004-WL103	Sample Date & Time Matrix 04/18/22 1017 DW	Clip Code	PWSID	JGS
Sample type:	Sample Event:	Facility ID:	Sample Point ID:	Static ID:	

Method SW 8015B SW 8015B	Prep Method EPA 5030C EPA 3550B	Analysis Requested (SUB)Gas Fraction Hydrocarbons TPH 8015 Diesel and Motor Oil
--------------------------------	---------------------------------------	---

Sample ID 202204200840	Client Sample ID for reference on TB: AIEA WELLS P2 (260)-331-004-WL103	Sample Date & Time Matrix 04/18/22 1017 DW	Clip Code	PWSID	JGS
Sample type:	Sample Event:	Facility ID:	Sample Point ID:	Static ID:	

Method SW 8015B	Prep Method EPA 5030C	Analysis Requested (SUB)Gas Fraction Hydrocarbons
--------------------	--------------------------	--

Relinquished by: [Signature] Sample Control
 Received by: [Signature]
 Relinquished by: [Signature] Sample Control
 Received by: [Signature]

Date 4/21/22 Time 17:43
 Date 4/21/22 Time 11:43
 Date _____ Time _____
 Date _____ Time _____

NOTIFICATION REQUIRED IF RECEIVED OUTSIDE OF 0-6 CELSIUS

An Acknowledgement of Receipt is requested to attn: Jackie Contreras

Temp 0.3/0.5
0.8/1.0



Type of Delivery <input type="checkbox"/> Fedex <input type="checkbox"/> UPS <input type="checkbox"/> GSO <input type="checkbox"/> Others	Airbill / Tracking Number	ECN <u>22D210</u>
<input type="checkbox"/> EMAX Courier <input checked="" type="checkbox"/> Client Delivery		Recipient <u>Arian Ramos</u>
		Date <u>4/21/22</u> Time <u>11:43</u>

COC INSPECTION

<input checked="" type="checkbox"/> Client Name	<input type="checkbox"/> Client PM/FC	<input type="checkbox"/> Sampler Name	<input checked="" type="checkbox"/> Sampling Date/Time	<input checked="" type="checkbox"/> Sample ID	<input checked="" type="checkbox"/> Matrix
<input checked="" type="checkbox"/> Address	<input type="checkbox"/> Tel # / Fax #	<input checked="" type="checkbox"/> Courier Signature	<input checked="" type="checkbox"/> Analysis Required	<input type="checkbox"/> Preservative (if any)	<input type="checkbox"/> TAT
Safety Issues (if any)	<input type="checkbox"/> High concentrations expected	<input type="checkbox"/> From Superfund Site	<input type="checkbox"/> Rad screening required		

Note: _____


PACKAGING INSPECTION

Container <u>Correction</u>	<input checked="" type="checkbox"/> Cooler	<input type="checkbox"/> Box	<input type="checkbox"/> Other
Condition <u>factor</u>	<input type="checkbox"/> Custody Seal	<input type="checkbox"/> Intact	<input type="checkbox"/> Damaged
Packaging <u>factor</u>	<input checked="" type="checkbox"/> Bubble Pack	<input type="checkbox"/> Styrofoam	<input type="checkbox"/> Popcorn
Temperatures (Cool, ≤6 °C but not frozen)	<input checked="" type="checkbox"/> Cooler 1 <u>10.3/0.5 °C</u>	<input checked="" type="checkbox"/> Cooler 2 <u>0.8/1.0 °C</u>	<input type="checkbox"/> Cooler 3 _____ °C
Thermometer: <u>A-S/N 210583979</u>	<input type="checkbox"/> Cooler 6 _____ °C	<input type="checkbox"/> Cooler 7 _____ °C	<input type="checkbox"/> Cooler 8 _____ °C
	<input type="checkbox"/> Cooler 9 _____ °C	<input type="checkbox"/> Cooler 10 _____ °C	

Comments: Temperature is out of range. PM was informed IMMEDIATELY.

Note: _____

DISCREPANCIES

LabSampleID	LabSampleContainerID	Code	ClientSample Label ID / Information	Corrective Action
1	7-12	D1	Jet fuel 5 not indicated in COC	R8
1	4-12	D1		R1
				

pH holding time requirement for water samples is 15 mins. Water samples for pH analysis are received beyond 15 minutes from sampling time. NO 4/21/22

NOTES/OBSERVATIONS:
SAMPLE MATRIX IS DRINKING WATER? YES NO

- LEGEND:**
- | | | |
|--|--|---|
| <p>Code Description- Sample Management</p> <p><u>D1</u> Analysis is not indicated in <u>label COC</u></p> <p>D2 Analysis mismatch COC vs label</p> <p>D3 Sample ID mismatch COC vs label</p> <p>D4 Sample ID is not indicated in _____</p> <p>D5 Container -[improper] [leaking] [broken]</p> <p>D6 Date/Time is not indicated in _____</p> <p><u>D7</u> <u>Date/Time</u> mismatch COC vs <u>label</u></p> <p>D8 Sample listed in COC is not received</p> <p>D9 Sample received is not listed in COC</p> <p>D10 No initial/date on corrections in COC/label</p> <p>D11 Container count mismatch COC vs received</p> <p>D12 Container size mismatch COC vs received</p> | <p>Code Description-Sample Management</p> <p>D13 Out of Holding Time</p> <p>D14 Bubble is >6mm</p> <p>D15 No trip blank in cooler</p> <p>D16 Preservation not indicated in _____</p> <p>D17 Preservation mismatch COC vs label</p> <p>D18 Insufficient chemical preservative</p> <p>D19 Insufficient Sample</p> <p>D20 No filtration info for dissolved analysis</p> <p>D21 No sample for moisture determination</p> <p>D22 _____</p> <p>D23 _____</p> <p>D24 _____</p> | <p><input type="checkbox"/> Continue to next page.</p> <p>Code Description-Sample Management</p> <p>R1 Proceed as indicated in <u>COC</u> <input type="checkbox"/> Label</p> <p>R2 Refer to attached instruction</p> <p>R3 Cancel the analysis</p> <p>R4 Use vial with smallest bubble first</p> <p>R5 Log-in with latest sampling date and time+1 min</p> <p>R6 Adjust pH as necessary</p> <p>R7 Filter and preserved as necessary</p> <p>R8 <u>Informed Client</u></p> <p>R9 _____</p> <p>R10 _____</p> <p>R11 _____</p> <p>R12 _____</p> |
|--|--|---|

REVIEWS:

Sample Labeling JHOWIN Zamora Riquelme
Date 4/21/22 4/21/22

SRF Alpitero
Date 4/21/22

PM AB
Date 4/21/22

REPORTING CONVENTIONS

DATA QUALIFIERS:

Lab Qualifier	AFCEE Qualifier	Description
J	F	Indicates that the analyte is positively identified and the result is less than RL but greater than MDL.
N		Indicates presumptive evidence of a compound.
B	B	Indicates that the analyte is found in the associated method blank as well as in the sample at above QC level.
E	J	Indicates that the result is above the maximum calibration range or estimated value.
*	*	Out of QC limit.

Note: The above qualifiers are used to flag the results unless the project requires a different set of qualification criteria.

ACRONYMS AND ABBREVIATIONS:

CRDL	Contract Required Detection Limit
RL	Reporting Limit
MRL	Method Reporting Limit
PQL	Practical Quantitation Limit
MDL	Method Detection Limit
DO	Diluted out

DATES

The date and time information for leaching and preparation reflect the beginning date and time of the procedure unless the method, protocol, or project specifically requires otherwise.

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

1000367

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

SDG#: 22D210

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 1000367

SDG : 22D210

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

A total of two(2) water samples were received on 04/21/22 to be analyzed for Total Petroleum Hydrocarbons by Purge and Trap in accordance with Method 5030B/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. VG39D09B - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. VG39D09L/VG39D09C were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Gasoline was within MS QC limits in D210-01M/D210-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogate was added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project     : 1000367
=====
SDG NO.    : 22D210
Instrument ID : GC1039
=====

```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	WATER		Extraction Date/Time	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
				Analysis Date/Time	Extraction Date/Time					
MBLK1W	VG39D09B	1	NA	04/22/2212:14	04/22/2212:14	ED22005A	ED22003A	22VG39D09	Method Blank	
LCS1W	VG39D09L	1	NA	04/22/2212:51	04/22/2212:51	ED22006A	ED22003A	22VG39D09	Lab Control Sample (LCS)	
LCD1W	VG39D09C	1	NA	04/22/2213:28	04/22/2213:28	ED22007A	ED22003A	22VG39D09	LCS Duplicate	
202204200839	D210-01	1	NA	04/22/2214:04	04/22/2214:04	ED22008A	ED22003A	22VG39D09	Field Sample	
202204200839MS	D210-01M	1	NA	04/22/2214:41	04/22/2214:41	ED22009A	ED22003A	22VG39D09	Matrix Spike Sample (MS)	
202204200839MSD	D210-01S	1	NA	04/22/2215:18	04/22/2215:18	ED22010A	ED22003A	22VG39D09	MS Duplicate (MSD)	
202204200840	D210-02	1	NA	04/22/2215:55	04/22/2215:55	ED22011A	ED22003A	22VG39D09	Field Sample	

```

=====
FN          - Filename
% Moist     - Percent Moisture
=====

```

SAMPLE RESULTS

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL      Date Collected: 04/18/22 10:17
Project     : 1000367                        Date Received: 04/21/22
Batch No.   : 22D210                         Date Extracted: 04/22/22 14:04
Sample ID   : 202204200839                  Date Analyzed: 04/22/22 14:04
Lab Samp ID : D210-01                        Dilution Factor: 1
Lab File ID : ED22008A                       Matrix: WATER
Ext Btch ID : 22VG39D09                      % Moisture: NA
Calib. Ref. : ED22003A                       Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0337	0.0400	84	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

=====
Client : EUROFINS EATON ANALYTICAL Date Collected: 04/18/22 10:17
Project : 1000367 Date Received: 04/21/22
Batch No. : 22D210 Date Extracted: 04/22/22 15:55
Sample ID : 202204200840 Date Analyzed: 04/22/22 15:55
Lab Samp ID: D210-02 Dilution Factor: 1
Lab File ID: ED22011A Matrix: WATER
Ext Btch ID: 22VG39D09 % Moisture: NA
Calib. Ref.: ED22003A Instrument ID: 39
=====

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0338	0.0400	84	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

QC SUMMARIES

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 04/22/22 12:14
Project     : 1000367                     Date Received: 04/22/22
Batch No.   : 22D210                      Date Extracted: 04/22/22 12:14
Sample ID   : MBLK1W                      Date Analyzed: 04/22/22 12:14
Lab Samp ID : VG39D09B                   Dilution Factor: 1
Lab File ID : ED22005A                   Matrix: WATER
Ext Btch ID : 22VG39D09                  % Moisture: NA
Calib. Ref.: ED22003A                   Instrument ID: 39
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0340	0.0400	85	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 1000367
BATCH NO. : 22D210
METHOD : 5030B/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : MBLK1W                             LCS1W      LCD1W
LAB SAMPLE ID : VG39D09B                         VG39D09L   VG39D09C
LAB FILE ID  : ED22005A                         ED22006A   ED22007A
DATE PREPARED : 04/22/22 12:14                  04/22/22 12:51  04/22/22 13:28
DATE ANALYZED : 04/22/22 12:14                  04/22/22 12:51  04/22/22 13:28
PREP BATCH   : 22VG39D09                       22VG39D09   22VG39D09
CALIBRATION REF: ED22003A                       ED22003A    ED22003A
=====
  
```

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.484	97	0.500	0.475	95	2	60-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0447	112	0.0400	0.0434	109	70-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 1000367
BATCH NO. : 22D210
METHOD : 5030B/8015B

```

=====
MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1 1
SAMPLE ID : 202204200839 202204200839MS 202204200839MSD
LAB SAMPLE ID : D210-01 D210-01M D210-01S
LAB FILE ID : ED22008A ED22009A ED22010A
DATE PREPARED : 04/22/22 14:04 04/22/22 14:41 04/22/22 15:18
DATE ANALYZED : 04/22/22 14:04 04/22/22 14:41 04/22/22 15:18
PREP BATCH : 22VG39D09 22VG39D09 22VG39D09
CALIBRATION REF: ED22003A ED22003A ED22003A
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.451	90	0.500	0.455	91	1	50-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0430	108	0.0400	0.0434	109	60-140

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

1000367

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

SDG#: 22D210

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 1000367

SDG : 22D210

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 04/21/22 to be analyzed for Total Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSD022WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for Diesel was within LCS QC limits in DSD022WL. Both opening and closing calibration verifications were within QC limits. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project     : 1000367
=====
SDG NO.    : 22D210
Instrument ID : D5
=====

```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	WATER		Extraction Date/Time	Sample Data FN	Calibration Prep. Data FN	Notes
				Analysis Date/Time	% Moist				
MBLK1W	DSD022WB	1	NA	04/27/2214:34	04/25/2210:15	LD27008A	LD27004A	22DSD022W	Method Blank
LCS1W	DSD022WL	1	NA	04/27/2214:53	04/25/2210:15	LD27009A	LD27004A	22DSD022W	Lab Control Sample (LCS)
202204200839	D210-01	1	NA	04/27/2215:11	04/25/2210:15	LD27010A	LD27004A	22DSD022W	Field Sample

```

FN      - Filename
% Moist - Percent Moisture

```

SAMPLE RESULTS

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 04/18/22 10:17
Project     : 1000367                     Date Received: 04/21/22
Batch No.   : 22D210                       Date Extracted: 04/25/22 10:15
Sample ID   : 202204200839                 Date Analyzed: 04/27/22 15:11
Lab Samp ID: 22D210-01                     Dilution Factor: 1
Lab File ID: LD27010A                       Matrix: WATER
Ext Btch ID: 22DSD022W                     % Moisture: NA
Calib. Ref.: LD27004A                       Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)		
Diesel	ND	0.026	0.013		
Motor Oil	ND	0.052	0.026		
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT	
Bromobenzene	0.433	0.525	82	60-130	
Hexacosane	0.118	0.131	90	60-130	

Notes:

Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 950ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

QC SUMMARIES

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 04/25/22 10:15
Project     : 1000367                     Date Received: 04/25/22
Batch No.   : 22D210                       Date Extracted: 04/25/22 10:15
Sample ID   : MBLK1W                       Date Analyzed: 04/27/22 14:34
Lab Samp ID: DSD022WB                      Dilution Factor: 1
Lab File ID: LD27008A                      Matrix: WATER
Ext Btch ID: 22DSD022W                    % Moisture: NA
Calib. Ref.: LD27004A                     Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)		
Diesel	ND	0.025	0.012		
Motor Oil	ND	0.050	0.025		
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT	
Bromobenzene	0.392	0.500	78	60-130	
Hexacosane	0.103	0.125	82	60-130	

Notes:

Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 1000367
BATCH NO. : 22D210
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSD022WB DSD022WL
LAB FILE ID : LD27008A LD27009A
DATE PREPARED : 04/25/22 10:15 04/25/22 10:15
DATE ANALYZED : 04/27/22 14:34 04/27/22 14:53
PREP BATCH : 22DSD022W 22DSD022W
CALIBRATION REF: LD27004A LD27004A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Diesel	ND	2.50	2.16	86	50-130

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.481	96	60-130
Hexacosane	0.125	0.117	94	60-130

MB: Method Blank sample LCS: Lab Control Sample