


750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Report

for

Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg.” Room 308
Honolulu, HI 96843
Attention: Erwin Kawata
Fax: 808-550-5018



Utah ELCP CA00006

DEB: Debbie L Frank
Project Manager

Report: 978568
Project: RED-HILL
Group: Red-Hill Expanded List (Albuquerque+)

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all **TNI 2016 and ISO/IEC 17025:2017** requirements unless noted under the individual analysis.

* As applicable, this report consists of the cover page, State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	NE-OS-21-13
Arkansas	CA00006	Nevada	CA00006
California	2813	New Hampshire *	2959
Colorado	CA00006	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	CA00006
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	21-008R	Ohio - 537.1	87786
Hawaii	CA00006	Oregon *	4034
Idaho	CA00006	Pennsylvania *	68-00565
Illinois	200033	Puerto Rico	CA00006
Indiana	C-CA-01	Rhode Island	LAO00326
Iowa – Asbestos	413	South Carolina	87016
Kansas *	E-10268	South Dakota	CA11320
Kentucky	90107	Tennessee	TN02839
Louisiana *	LA008	Texas *	T104704230-20-18
Maine	CA00006	Utah (Primary AB) *	CA00006
Maryland	224	Vermont	VT0114
Marianas Islands	MP0004	Virginia *	460260
Massachusetts	M-CA006	Washington	C838
Michigan	9906	EPA Region 5	CA00006
Mississippi	CA00006	Los Angeles County Sanitation Districts	10264

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025:2917 Accredited Method List

The test listed below are accredited and met the requirements of ISO/IEC 17025 as verify by A2LA.

Refer to our certificates and scope of accreditations (no. 5890-1 and 5890-2) found at:

<https://www.eurofinsus.com/Eaton>

Test(s)	Method(s)	Potable Water *	Waste Water	Test(s)	Method(s)	Potable Water *	Waste Water
Enterococci	Enterolert	x	x	Gross Alpha coprecipitation	SM 7110 C	x	x
Escherichia coli (Enumeration)	SM 9221 B.1 SM 9221 F	x		Hardness	SM 2340 B	x	x
Fecal Coliform (P/A and Enumeration)	SM 9221 C (MTF/EC), SM 9221 E (MTF/EC)	x	x	Hexavalent Chromium	EPA 218.6,	x	x
Fecal Streptococci and Enterococci	SM 9230 B	x	x	Hexavalent Chromium	EPA 218.7,	x	
Heterotrophic Bacteria	SM 9215 B	x		Hexavalent Chromium	SM 3500-Cr B		x
Legionella	Legiolert®	x		Inorganic Anions and DBPs	EPA 300.0	x	x
Pseudomonas aeruginosa	Idexx Pseudalart	x		Norganic Anions and DBPs	EPA 300.1	x	
Total Coliform (P/A and Enumeration)	SM 9221A, SM 9221B, SM 9221 C	x	x	Kjeldahl Nitrogen	EPA 351.2		x
Total Coliform, Total Coliform with Chlorine Present	SM 9221 B	x	x	Metals	EPA 200.7, EPA200.8	x	x
Total Coliform/E. coli (P/A and Enumeration, Idexx Colilert, Idexx Colilert 18, Colisure)	SM 9223	x		Nitrosamines	EEA-Agilent 521.1 (GCMS-24250)	x	
Total Microcystins and Nodularins	EPA 546	X		Nitrate/Nitrite Nitrogen	EPA 353.2	x	x
Yeast and Mold	SM 9610	x		Odor	SM2150B	x	
1,2,3-Trichloropropane (TCP) at 5 PPT	CA SRL 524M-TCP	x		Organohalide Pesticides and PCB	EPA 505	x	
1,4-Dioxane	EPA 522	x		Ortho Phosphate	SM 4500P E	x	
2,3,7,8-TCDD	Modified EPA 1613 B	x		Oxyhalides Disinfection Byproducts	EPA 317.0	x	
Acrylamide	+ LCMS 2440)	x		Perchlorate	EPA 331.0	x	
Algal Toxins/Microcystin	+ LCMS 3570	x		Perchlorate (Low and High Levels)	EPA 314.0	x	
Alkalinity	SM 2320B	x	x	Perfluorinated Alkyl Acids	EPA 533, EPA 537, EPA 537.1	x	
Ammonia	EPA 350.1, SM 4500-NH3 H		x	PPCP and EDC	+ LCMS-2443	x	
Asbestos	EPA 100.2	x	x	pH	EPA 150.1 SM 4500-H+ B	x	x
Bicarbonate Alkalinity as HCO3	SM 2330 B	x	x	Phenolics – Low Level	+WC 2493 (EPA 420.2 and EPA 420.4 MOD)	x	x
BOD/CBOD	SM 5210 B		x	Phenylurea Pesticides/Herbicides	+ LCMS-2448	x	
Bromate	+ LCMS- 2447	x		Radium-226, Radium-228	GA Tech (Rad-2374)	x	
Carbonate as CO3	SM 2330 B	x	x	Radon-222	SM 7500RN	x	
Carbonyls	EPA 556	x	x	Residue (Filterable)	SM 2540C	x	x
Chemical Oxygen Demand	EPA 410.4, SM 5220D		x	Residue (Non-Filterable)	SM 2540D		x
Chlorinated Acids	EPA 515.4	x		Residue (Total)	SM 2540B		x
Chlorine Dioxide	Palin Test Chlordio X Plus, SM 4500-CLO2 D	x		Residue (Volatile)	EPA 160.4		x
Chlorine, Free, Combined, Total Residual, Chloramines	SM 4500-Cl G	x		Semi-Volatile Compounds	EPA 525.2	x	
Color	SM2120B	x		Silica	SM 4500-SiO2 C	x	x
Conductivity	EPA 120.1, SM 2510B	x	x	Sulfide	SM 4500-S D		x
Corrosivity (Langelier Index), Carbonate as CO3, Hydroxide as OH Calculated	SM 2330 B	x		Sulfite	SM 4500-SO3 B	x	x
Cyanide (Amenable)	SM 4500-CN G	x	x	Surfactants	SM 5540C	x	x
Cyanide (Free)	SM 4500CN F	x	x	Taste and Odor	SM 6040 E	x	
Cyanide (Total)	EPA 335.4	x	x	Total Organic Carbon	SM 5310 C	x	x
Cyanogen Chloride (Screen)	+ 335 Mod (WC-24467)	x		Total Phenols	EPA 420.1		x
Diquat and Paraquat	EPA 549.2	x		Total Phenols	EPA 420.4	x	x
DBP and HAA	SM 6251 B	x		Triazine Pesticides and their Degradates	+ LCMS-3617	x	
Dissolved Organic Carbon	SM 5310 C	x		Turbidity	EPA 180.1	x	x
Dissolved Oxygen	SM 4500-O G		x	Uranium by ICP/MS	EPA 200.8	x	
EDB/DCBP/TCP	EPA 504.1	x		UV 254 Organic Constituents	SM 5910B	x	
EDB/DBCP and Disinfection Byproducts	EPA 551.1	x		VOCs	EPA 524.2	x	
EDTA and NTA	+ WC-2454	x		VOCs	+ (GCMS 2412) by EPA 524.2 modified	x	
Endothall	EPA 548.1, +(LCMS-2445)	x					
Fluoride	SM 4500F C	x	x				
Glyphosate	EPA 547	x					
Glyphosate and AMPA	+ LCMS-3618	x					
Gross Alpha and Gross Beta	EPA 900.0	x	x				

(*) includes: Bottled Water, Drinking Water and Water as Component of Food & Beverage.

(+) In-House Method

Acknowledgement of Samples Received

Addr: **Honolulu Board of Water Supply**
 630 South Beretania Street
 Public Service Bldg." Room 308
 Honolulu, HI 96843

Attn: Erwin Kawata
 Phone: 808-748-5091

Client ID: HONOLULU
 Folder #: 978568
 Project: RED-HILL
 Sample Group: Red-Hill Expanded List
 (Albuquerque+)
 Project Manager: Debbie L Frank
 Phone: (626) 386-1149
 PO #: C20525101 exp 05312023

The following samples were received from you on **January 05, 2022** at **1115**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
<u>202201050306</u>	AIEA WELLS PUMP 2 (HI0000331-004) SDWIS PWSID: HI0000331 SDWIS SAMPLE POINT ID: 004 Static ID: AIEA WELLS PUMP 2 (SUB)Gas Fraction Hydrocarbons TPH 8015 Diesel and Motor Oil TPH 8015 Jet Fuel 5 TPH 8015 Jef Fuel 8	01/04/2022 0950
<u>202201050307</u>	TRAVEL BLANK:: AIEA WELLS PUMP 2 (SUB)Gas Fraction Hydrocarbons	01/04/2022 0950
<u>202201050308</u>	HALAWA WELLS PUMP 2 (HI0000331-024) SDWIS PWSID: HI0000331 SDWIS SAMPLE POINT ID: 024 Static ID: HALAWA WELLS PUMP 2 (SUB)Gas Fraction Hydrocarbons TPH 8015 Diesel and Motor Oil TPH 8015 Jet Fuel 5 TPH 8015 Jef Fuel 8	01/04/2022 0930
<u>202201050309</u>	TRAVEL BLANK:: HALAWA WELLS PUMP 2 (SUB)Gas Fraction Hydrocarbons	01/04/2022 0930

Test Description



Eaton Analytical

CHAIN OF CUSTODY RECORD

EUROFINS EATON ANALYTICAL USE ONLY:

750 Royal Oaks Drive, Suite 100
 Monrovia, CA 91016-3629
 Phone: 626 386 1100
 Fax: 626 386 1101
 800 566 LABS (800 566 5227)

LOGIN COMMENTS: _____

SAMPLES CHECKED AGAINST COC BY: _____

SAMPLES LOGGED IN BY: _____

SAMPLES REC'D DAY OF COLLECTION? (check for yes)

SAMPLE TEMP RECEIVED AT: _____ °C (Compliance: 4 ± 2 °C)

Colton / No. California / Arizona 2.7 °C (Compliance: 4 ± 2 °C)

Monrovia

CONDITION OF BLUE/ICE: Frozen Partially Frozen _____ Thawed _____

Wet Ice _____ No Ice _____

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEX / UPS / DHL / Area Fast / Top Line / Other: _____

GA 5568

TO BE COMPLETED BY SAMPLER:

COMPANY/AGENCY NAME: BWS HONOLULU

PROJECT CODE: Red Hill

SAMPLE GROUP: _____

COC ID: _____

SEE ATTACHED BOTTLE ORDER FOR ANALYSES

list ANALYSES REQUIRED (enter number of bottles sent for each test for each sample)

COMPLIANCE SAMPLES	NON-COMPLIANCE SAMPLES	SAMPLER COMMENTS
<input type="checkbox"/>	<input checked="" type="checkbox"/>	
- Requires state forms		
Type of samples (circle one): ROUTINE <input checked="" type="checkbox"/> SPECIAL <input type="checkbox"/> CONFIRMATION (eg. SDWA, Phase V, NPDES, FDA,....)		

Temp Blank: 0.0 °C

* MATRIX TYPES: RSW = Raw Surface Water CFW = Chlor(am)inated Finished Water SEAW = Sea Water BW = Bottled Water SO = Soil

RGW = Raw Ground Water FW = Other Finished Water WW = Waste Water SW = Storm Water SL = Sludge

O = Other - Please identify

SAMPLED BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
RELINQUISHED BY:		Derek Dotson	Honolulu Board of Water Supply	1-4-2022	
RECEIVED BY:		Derek Dotson	Honolulu Board of Water Supply	1-4-2022	1200
RELINQUISHED BY:		Victor Pascencia	GA	1.5.22	1115
RECEIVED BY:					



Eaton Analytical

Kit Order for Honolulu Board of Water Supply

Debbie L Frank is your Eurofins Eaton Analytical, LLC Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Created Date & Time: 12/10/2021 6:09:58PM

Note: Sampler Please return this paper with your samples

Client ID: HONOLULU



Project Code: RED-HILL Bottle Orders
Group Name: Red-Hill Expanded List (Albuquerque+)
PO#/JOB#: C20525101 exp 05312023
Description: HALAWA WELLS UNITS 1 & 2 - E1



Kit #: 307657

Created By: - [AutoGenerated]
Deliver By: 12/15/2021
STG: Bottle Orders

Ice Type: G

Pre Registered

Ship Sample Kits to
Honolulu Board of Water Supply
630 South Beretania Street
Chemistry Lab
Honolulu, HI 96843
Attn: Ron Fenstemacher
Phone: 808-748-5841
Fax: 808-550-5572

Send Report to
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808-748-5091
Fax: 808-550-5018

Billing Address
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808-748-5091
Fax: 808-550-5018

# of Sample	Tests	Bottle Qty - Type [preservative information]	Total	UN DOT #
1	@625A_Physis-G, @625BN_Physis-G, @625PAH_Physis-TICS-C	4 - 1L amber-glass [1 ml Thio 8%]	4	
1	TPH 8015 Diesel and Motor Oil_C, TPH 8015 Jet Fuel 5_C, TPH 8015 Jet Fuel 8_C	6 - 1L amber glass [1 ml Thio 8%]	6	
1	8015 Gas_C	3 - 40ml amber glass vial [1 drop Thio (8%)]	3	
1	8015 Gas_TB	2 - 40ml amber glass vial [1 drop Thio (8%) + H2O]	2	
1	@VOASDWA-G-plus-plus-TICs-TBG	3 - 40ml amber-glass-vial [25mg-AA+ H2O+10-drop-1:1-HCL]	3	UN1789
1	@VOASDWA-G-plus-plus-TICs-C	3 - 40ml amber-glass-vial [25mg-Ascorbio+drop-2ml 1:1-HCL]	3	UN1789
1	@8015 Ethanol_Subbed	3 - 40ml amber glass vial [no-preservative]	3	
Sum Tests: 7			Sum Bottles: 24	

Comments

SITE ID:
HALAWA WELLS (331-206-TP065)

SAMPLER:
FOUR 1 LITER AMBER GLASS BOTTLES FOR 625 SERIES AND SIX 1 LITER AMBER GLASS BOTTLES FOR TPH 8015 SERIES.

SHIPPING:
Travel Blanks - TBA/MTBE, VOASDWA - Prepare TBs in the VOA LAB.
Label Cooler on TOP and right below both Handles with Site description of contents (use extra Container Labels)

ASM: Be sure to coordinate Follow-up as needed for any new detections in Field samples.
Acetone - follow-ups need to use EPA 624



Eaton Analytical

Kit Order for Honolulu Board of Water Supply

Debbie L Frank is your Eurofins Eaton Analytical, LLC Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Created Date & Time: 12/10/2021 7:10:51PM

Note: Sampler Please return this paper with your samples

Kit #: 307672

Client ID: HONOLULU

Created By: - [AutoGenerated]
Deliver By: 12/22/2021
STG: Bottle Orders
Ice Type: G
Pre Registered

Project Code: RED-HILL Bottle Orders
Group Name: Red-Hill Expanded List (Albuquerque+)
PO#/JOB#: C20525101 exp 05312023
Description: AIEA WELLS PUMPS 1&2 (260) - 1

Ship Sample Kits to
Honolulu Board of Water Supply
630 South Beretania Street
Chemistry Lab
Honolulu, HI 96843
Attn: Ron Fenstermacher
Phone: 808-748-5841
Fax: 808-550-5572

Send Report to
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808-748-5091
Fax: 808-550-5018

Billing Address
Honolulu Board of Water Supply
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843
Attn: Erwin Kawata
Phone: 808-748-5091
Fax: 808-550-5018

# of Sample Tests	Bottle Qty - Type [preservative information]	Total	UN DOT #
1	@625A-Physis C, @625BN-Physis C, @625PAH-Physis-TICS-C 4 - 1L amber glass [1 ml Thio 8%]	4	
1	TPH 8015 Diesel and Motor Oil_C, TPH 8015 Jet Fuel 5_C, TPH 8015 Jet Fuel 8_C	6	
1	8015 Gas_C	3	
1	8015 Gas_C TB	2	
1	@VOASDWA-C plus plus TICs TBC	3	JUN1789
1	@VOASDWA-C plus plus TICs C	3	UN1799
1	@8015 Ethanol_Subbed	3	
Sum Tests: 7		Sum Bottles: 24	


Comments

AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)

SAMPLER:
Four 1 LITER AMBER GLASS BOTTLES FOR 625 SERIES AND Six 1 LITER AMBER GLASS BOTTLES FOR TPH 8015 SERIES.

SHIPPING:
Travel Blanks - TBA/MTBE, VOASDWA - Prepare TBs in the VOA LAB.
Label Cooler on TOP and right below both Handles with Site description of contents (use extra Containr Labels)

ASM: Be sure to coordinate Follow-up as needed for any new detections in Field samples.
Acetone - follow-ups need to use EPA 624



INTERNAL CHAIN OF CUSTODY RECORD

Eaton Analytical

EEA Folder Number: 097-6566

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMS know. ASMS will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes (No)

IR Gun ID = 630 (Observation = 2.9 °C) (Corr. Factor = -0.2 °C) (Final = 2.7 °C)

CONDITION OF ICE: Frozen Partially Frozen _____ Thawed _____ N/A _____

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx UPS / DHL / Area Fast / Top Line / Other: _____

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

- 4 Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)
- 5) pH Check. Manufacturer: _____ Lot Number: _____ pH strip type: 0 - 14 or _____ Expiration Date: _____ Results: _____
- 6) Chlorine check. Manufacturer: Sansafe. Lot No.: _____ Expiration Date: _____ Results: _____

7) VOA and Radon Headspace: No Samples with Headspace. Samples with Headspace (see below):

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(9267,662), 606, SP/ME, @CH, 532LCMS, 658, 698, Anatoxin, LCMS methods using 40 ml vials, International clients: None/<6

Samp ID	Bottle #	None/<6	>6mm	Test	Samp ID	Bottle #	None/<6	>6mm	Test

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors): _____

RECEIVED BY: [Signature] SIGNATURE PRINT NAME: Vivian Pascevic COMPANY/TITLE: Eurofins Eaton Analytical DATE: 1.5.22 TIME: 1115

SAMPLES CHECKED AGAINST COG BY: _____ SIGNATURE PRINT NAME: _____ COMPANY/TITLE: Eurofins Eaton Analytical DATE: _____ TIME: _____


ORIGIN ID: HIKA (808) 748-5840
BMS CHEM LAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST.
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE: 04JAN22
ACTWGT: 60.00 LB
CAD: 100205419/NET 4400
BILL RECIPIENT

TO C CHUCK

EUROFINS EATON ANALYTICAL, INC
750 ROYAL OAKS DR
SUITE 100
MONROVIA CA 91016
REF: (828) 386-1178
P.O. NV. DEPT.

56D.J201EFFE4A




1 of 2

TRK# 7756 6184 2655
[0201] # MASTER ##

WED - 05 JAN 10:30A
PRIORITY OVERNIGHT

WZ WHPA

91016
CA-US BUR



After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our Service Guide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Comments

Report: 978568
Project: RED-HILL
Group: Red-Hill Expanded List
(Albuquerque+)

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Folder Comments

Results for TPH Gas, Diesel, Motor Oil and Jet Fuels are submitted by EMAX Laboratories

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 978568
Project: RED-HILL
Group: Red-Hill Expanded List
(Albuquerque+)

Honolulu Board of Water Supply
Erwin Kawata
630 South Beretania Street
Public Service Bldg." Room 308
Honolulu, HI 96843

Samples Received on:
01/05/2022 1115

Analyzed	Analyte	Sample ID	Result	HI Limit	Units	MRL
----------	---------	-----------	--------	----------	-------	-----

Tel: (626) 386-1100
 Fax: (866) 988-3757
 1 800 566 LABS (1 800 566 5227)

Report: 978568
Project: RED-HILL
Group: Red-Hill Expanded List
 (Albuquerque+)

Honolulu Board of Water Supply
 Erwin Kawata
 630 South Beretania Street
 Public Service Bldg.™ Room 308
 Honolulu, HI 96843

Samples Received on:
 01/05/2022 1115

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<u>AIEA WELLS PUMP 2 (HI0000331-004) (202201050306)</u>						Sampled on 01/04/2022 0950			
Sample Point ID: 004									
PWSID: HI0000331									
Static ID: AIEA WELLS PUMP 2									
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/06/22	01/06/22 19:40			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1
SW 8015B - TPH 8015 Diesel and Motor Oil									
01/06/22	01/07/22 15:52			(SW 8015B)	TPH Diesel	ND	mg/L	0.028	1
01/06/22	01/07/22 15:52			(SW 8015B)	TPH Motor Oil	ND	mg/L	0.055	1
EPA 8015 - Jet Fuel 5 C8-C18									
01/06/22	01/07/22 15:52			(EPA 8015)	Jet Fuel 5	ND	mg/L	0.055	1
EPA 8015 - Jet Fuel 8 C8-C18									
	01/07/22 15:52			(EPA 8015)	Jet Fuel 8	ND	mg/L	0.055	1
<u>TRAVEL BLANK:: AIEA WELLS PUMP 2 (202201050307)</u>						Sampled on 01/04/2022 0950			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/06/22	01/06/22 20:14			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1
<u>HALAWA WELLS PUMP 2 (HI0000331-024) (202201050308)</u>						Sampled on 01/04/2022 0930			
Sample Point ID: 024									
PWSID: HI0000331									
Static ID: HALAWA WELLS PUMP 2									
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/06/22	01/06/22 20:48			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1
SW 8015B - TPH 8015 Diesel and Motor Oil									
01/06/22	01/07/22 16:45			(SW 8015B)	TPH Diesel	ND	mg/L	0.03	1
01/06/22	01/07/22 16:45			(SW 8015B)	TPH Motor Oil	ND	mg/L	0.059	1
EPA 8015 - Jet Fuel 5 C8-C18									
01/06/22	01/07/22 16:45			(EPA 8015)	Jet Fuel 5	ND	mg/L	0.059	1
EPA 8015 - Jet Fuel 8 C8-C18									
	01/07/22 16:45			(EPA 8015)	Jet Fuel 8	ND	mg/L	0.059	1
<u>TRAVEL BLANK:: HALAWA WELLS PUMP 2 (202201050309)</u>						Sampled on 01/04/2022 0930			
SW 8015B - (SUB)Gas Fraction Hydrocarbons									
01/06/22	01/06/22 21:22			(SW 8015B)	(SUB)Gas Fraction Hydrocarbons	ND	mg/L	0.02	1

Rounding on totals after summation.
 (c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.



3051 Fujita Street
 Torrance, CA 90505
 Tel: (310)-618-8889

Date: 01-18-2022
 EMAX Batch No.: 22A034

Attn: Jackie Contreras

Eurofins Eaton Analytical
 750 Royal Oaks Dr., Suite 100
 Monrovia, CA 91016-3629

Subject: Laboratory Report
 Project: 978568


Enclosed is the Laboratory report for samples received on 01/06/22.
 The data reported relate only to samples listed below :

Sample ID	Control #	Col Date	Matrix	Analysis
202201050306	A034-01	01/04/22	WATER	TPH GASOLINE TPH
202201050307	A034-02	01/04/22	WATER	TPH GASOLINE
202201050308	A034-03	01/04/22	WATER	TPH GASOLINE TPH
202201050309	A034-04	01/04/22	WATER	TPH GASOLINE
202201050306MS	A034-01M	01/04/22	WATER	TPH JP-5
202201050306MSD	A034-01S	01/04/22	WATER	TPH JP-5
202201050308MS	A034-03M	01/04/22	WATER	TPH JP-8
202201050308MSD	A034-03S	01/04/22	WATER	TPH JP-8

The results are summarized on the following pages.

Please feel free to call if you have any questions concerning these results.

Sincerely yours,


 Caspar J. Pang
 Laboratory Director

This report is confidential and intended solely for the use of the individual or entity to whom it is addressed. This report shall not be reproduced except in full or without the written approval of EMAX.

EMAX certifies that results included in this report meets all TNI & DOD requirements unless noted in the Case Narrative.

NELAP Accredited Certificate Number CA002912021-19
 ANAB Accredited DoD ELAP and ISO/IEC 17025 Certificate Number L2278 Testing
 California ELAP Accredited Certificate Number 2672

Submittal Form

22 A034

Date: 1/6/2022

*REPORTING REQUIREMENTS: Do Not Combine Reports with any other samples submitted under different Folder Numbers!
Report & Invoice must have the Folder # 978568 Job # 1000014

Report all quality control data according to Method. Include dates analyzed. Date extracted (if extracted) and Method reference on the report.
Results must have Complete data & QC with Approval Signature.

Provide in each Report the
Specified State Certification # and
Exp. Date for requested tests + matrix.
Samples from: HAWAII

Reports: Jackie Contreras Sub-Contracting Administrator
EMAIL TO: Eaton-MonroviaSubContract@eurofins.com
Eurofins Eaton Analytical, LLC 750 Royal Oaks Drive, Suite 100, Monrovia, CA 91016
Phone (626) 386-1165 Fax (626) 386-1122
Invoices to: Eurofins Eaton Analytical LLC
Accounts Payable 2425 New Holland Pike, Lancaster, PA 17605

Red Hell Rush

eurolfins | Eaton Analytical

Ship To:
EMAX Laboratories, Inc.
3051 Fujita St.
Torrance, CA 90505

Phone: 310-618-8889 Fax: 310-618-0818

Folder #: 978568 Report Due: 01/10/2022

Sample ID	Client Sample ID for reference onl	Sample Date & Time	Matrix	Clip Code	PWSID
202201060306	AIEA WELLS PUMP 2 (H10000331-004)	01/04/22	0950 DW		JLS

Method	Prep Method	Analysis Requested	Sample Event	Facility ID:	Sample Point ID:	Static ID:
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons				
SW 8015B	EPA 3550B	TPH 8015 Diesel and Motor Oil				
EPA 8015	EPA 8015	Jet Fuel 5 C8-C18				
EPA 8015		Jet Fuel 8 C8-C18				

Sample ID	Client Sample ID for reference onl	Sample Date & Time	Matrix	Clip Code	PWSID
202201060307	TRAVEL BLANK AIEA WELLS PUMP 2	01/04/22	0950 DW		JLS

Method	Prep Method	Analysis Requested	Sample Event	Facility ID:	Sample Point ID:	Static ID:
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons				

Temp: 05.6 @ 5.1

NOTIFICATION REQUIRED IF RECEIVED OUTSIDE OF 0-6 CELSIUS

An Acknowledgement of Receipt is requested to attn: Jackie Contreras

Relinquished by: *[Signature]* Date: 1/6/22 Time: 11:05

Received by: *[Signature]* Date: 1/6/22 Time: 11:05

Relinquished by: _____ Date: _____ Time: _____

Received by: _____ Date: _____ Time: _____

66TU27

Sample ID 202201050308	Client Sample ID for reference on/ HALAWA WELLS PUMP 2 (H10000331-024)	Sample Date & Time Matrix 01/04/22 0930 DW	Clip Code	PWSID	JLS
Sample type:	Sample Event:	Sample Point ID:	Static ID: HALAWA WELLS		

Method	Prep Method	Analysis Requested
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons
SW 8015B	EPA 3550B	TPH 8015 Diesel and Motor Oil
EPA 8015	EPA 8015	Jet Fuel 5 C8-C18
EPA 8015		Jet Fuel 8 C8-C18

Sample ID 202201050309	Client Sample ID for reference on/ TRAVEL BLANK: HALAWA WELLS PUMP 2	Sample Date & Time Matrix 01/04/22 0930 DW	Clip Code	PWSID	JLS
Sample type:	Sample Event:	Sample Point ID:	Static ID:		

Method	Prep Method	Analysis Requested
SW 8015B	EPA 5030C	(SUB)Gas Fraction Hydrocarbons

Relinquished by: [Signature] Date 1/6/22 Time 11:05

Received by: [Signature] Date 1/6/22 Time 11:05

Relinquished by: _____ Date _____ Time _____

Received by: _____ Date _____ Time _____

NOTIFICATION REQUIRED IF RECEIVED OUTSIDE OF 0-6 CELSIUS

An Acknowledgement of Receipt is requested to attn: Jackie Contreras

Type of Delivery	Airbill / Tracking Number	ECN <u>22A034</u>
<input type="checkbox"/> Fedex <input type="checkbox"/> UPS <input type="checkbox"/> GSO <input type="checkbox"/> Others		Recipient <u>Alan Ramos</u>
<input type="checkbox"/> EMAX Courier <input checked="" type="checkbox"/> Client Delivery		Date <u>01/06/22</u> Time <u>11:05</u>

COC INSPECTION

<input checked="" type="checkbox"/> Client Name	<input checked="" type="checkbox"/> Client PM/FC	<input type="checkbox"/> Sampler Name	<input checked="" type="checkbox"/> Sampling Date/Time	<input checked="" type="checkbox"/> Sample ID	<input checked="" type="checkbox"/> Matrix
<input checked="" type="checkbox"/> Address	<input checked="" type="checkbox"/> Tel # / Fax #	<input type="checkbox"/> Courier Signature	<input checked="" type="checkbox"/> Analysis Required	<input type="checkbox"/> Preservative (if any)	<input checked="" type="checkbox"/> TAT
Safety Issues (if any)	<input type="checkbox"/> High concentrations expected	<input type="checkbox"/> From Superfund Site	<input type="checkbox"/> Rad screening required		

Note: _____

PACKAGING INSPECTION

Container	<input checked="" type="checkbox"/> Cooler	<input type="checkbox"/> Box	<input type="checkbox"/> Other
Condition	<input type="checkbox"/> Custody Seal	<input type="checkbox"/> Intact	<input type="checkbox"/> Damaged
Packaging	<input checked="" type="checkbox"/> Bubble Pack	<input type="checkbox"/> Styrofoam	<input type="checkbox"/> Popcorn
Temperatures (Cool, ≤6 °C but not frozen)	<input checked="" type="checkbox"/> Cooler 1 <u>5.6</u> °C	<input checked="" type="checkbox"/> Cooler 2 <u>5.1</u> °C	<input type="checkbox"/> Cooler 3 _____ °C
	<input type="checkbox"/> Cooler 6 _____ °C	<input type="checkbox"/> Cooler 7 _____ °C	<input type="checkbox"/> Cooler 8 _____ °C
Thermometer:	A - S/N <u>210191066</u>	B - S/N <u>210271396</u>	C - S/N <u>210271399</u>

Comments: Temperature is out of range. PM was informed IMMEDIATELY.

Note: _____

DISCREPANCIES

LabSampleID	LabSampleContainerID	Code	ClientSample Label ID / Information	Corrective Action
<u>1-4</u>	<u>1-10</u>	<u>D10</u>		<u>R1</u>
<u>1,3</u>	<u>4-7, 13-16</u>	<u>D2</u>	<u>Jet Fuel 0 is not indicated on label</u>	<u>R1</u>
<div style="border: 1px solid black; width: 100%; height: 100%; transform: rotate(45deg); opacity: 0.5;"></div>				

1/6/22

AS
1/7/22

pH holding time requirement for water samples is 15 mins. Water samples for pH analysis are received beyond 15 minutes from sampling time.

NOTES/OBSERVATIONS:

LEGEND:

<p>Code Description-Sample Management</p> <p>D1 Analysis is not indicated in _____</p> <p><u>D2</u> Analysis mismatch COC vs label</p> <p>D3 Sample ID mismatch COC vs label</p> <p>D4 Sample ID is not indicated in _____</p> <p>D5 Container -[improper] [leaking] [broken]</p> <p>D6 Date/Time is not indicated in _____</p> <p>D7 Date/Time mismatch COC vs label</p> <p>D8 Sample listed in COC is not received</p> <p>D9 Sample received is not listed in COC</p> <p><u>D10</u> No initial/date on corrections in COC(label)</p> <p>D11 Container count mismatch COC vs received</p> <p>D12 Container size mismatch COC vs received</p>	<p>Code Description-Sample Management</p> <p>D13 Out of Holding Time</p> <p>D14 Bubble is >6mm</p> <p>D15 No trip blank in cooler</p> <p>D16 Preservation not indicated in _____</p> <p>D17 Preservation mismatch COC vs label</p> <p>D18 Insufficient chemical preservative</p> <p>D19 Insufficient Sample</p> <p>D20 No filtration info for dissolved analysis</p> <p>D21 No sample for moisture determination</p> <p>D22 _____</p> <p>D23 _____</p> <p>D24 _____</p>	<p><input type="checkbox"/> Continue to next page.</p> <p>Code Description-Sample Management</p> <p><u>R1</u> Proceed as indicated in <input type="checkbox"/> COC <input type="checkbox"/> Label</p> <p>R2 Refer to attached instruction</p> <p>R3 Cancel the analysis</p> <p>R4 Use vial with smallest bubble first</p> <p>R5 Log-in with latest sampling date and time+1 min</p> <p>R6 Adjust pH as necessary</p> <p>R7 Filter and preserved as necessary</p> <p>R8 _____</p> <p>R9 _____</p> <p>R10 _____</p> <p>R11 _____</p> <p>R12 _____</p>
--	---	--

REVIEWS:

<p>Sample Labeling <u>Jocelyne Solis-Ramos</u></p> <p>Date <u>01/06/22</u></p>	<p>SRF <u>[Signature]</u></p> <p>Date <u>1/6/22</u></p>	<p>PM <u>[Signature]</u></p> <p>Date <u>1/7/22</u></p>
--	---	--

REPORTING CONVENTIONS

DATA QUALIFIERS:

Lab Qualifier	AFCEE Qualifier	Description
J	F	Indicates that the analyte is positively identified and the result is less than RL but greater than MDL.
N		Indicates presumptive evidence of a compound.
B	B	Indicates that the analyte is found in the associated method blank as well as in the sample at above QC level.
E	J	Indicates that the result is above the maximum calibration range or estimated value.
*	*	Out of QC limit.

Note: The above qualifiers are used to flag the results unless the project requires a different set of qualification criteria.

ACRONYMS AND ABBREVIATIONS:

CRDL	Contract Required Detection Limit
RL	Reporting Limit
MRL	Method Reporting Limit
PQL	Practical Quantitation Limit
MDL	Method Detection Limit
DO	Diluted out

DATES

The date and time information for leaching and preparation reflect the beginning date and time of the procedure unless the method, protocol, or project specifically requires otherwise.

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

978568

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

SDG#: 22A034

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 978568

SDG : 22A034

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

A total of four(4) water samples were received on 01/06/22 to be analyzed for Total Petroleum Hydrocarbons by Purge and Trap in accordance with Method 5030B/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. VGH7A02B - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. VGH7A02L/VGH7A02C were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG. Gasoline was within MS QC limits in A033-01M/A033-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogate was added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

SAMPLE RESULTS

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:50
Project     : 978568                      Date Received: 01/06/22
Batch No.   : 22A034                      Date Extracted: 01/06/22 19:40
Sample ID   : 202201050306               Date Analyzed: 01/06/22 19:40
Lab Samp ID : A034-01                    Dilution Factor: 1
Lab File ID : AA06012A                   Matrix: WATER
Ext Btch ID: 22VGH7A02                   % Moisture: NA
Calib. Ref.: AA06003A                   Instrument ID: H7
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0358	0.0400	90	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:50
Project     : 978568                     Date Received: 01/06/22
Batch No.   : 22A034                     Date Extracted: 01/06/22 20:14
Sample ID   : 202201050307              Date Analyzed: 01/06/22 20:14
Lab Samp ID: A034-02                     Dilution Factor: 1
Lab File ID: AA06013A                    Matrix: WATER
Ext Btch ID: 22VGH7A02                   % Moisture: NA
Calib. Ref.: AA06003A                    Instrument ID: H7
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0365	0.0400	91	60-140

Notes:
Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:30
Project     : 978568                      Date Received: 01/06/22
Batch No.   : 22A034                      Date Extracted: 01/06/22 21:22
Sample ID   : 202201050309              Date Analyzed: 01/06/22 21:22
Lab Samp ID : A034-04                    Dilution Factor: 1
Lab File ID : AA06015A                   Matrix: WATER
Ext Btch ID : 22VGH7A02                  % Moisture: NA
Calib. Ref.: AA06003A                    Instrument ID: H7
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0376	0.0400	94	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

QC SUMMARIES

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/06/22 15:39
Project     : 978568                      Date Received: 01/06/22
Batch No.   : 22A034                      Date Extracted: 01/06/22 15:39
Sample ID   : MBLK1W                      Date Analyzed: 01/06/22 15:39
Lab Samp ID: VGH7A02B                    Dilution Factor: 1
Lab File ID: AA06005A                    Matrix: WATER
Ext Btch ID: 22VGH7A02                   % Moisture: NA
Calib. Ref.: AA06003A                    Instrument ID: H7
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
GASOLINE	ND	0.020	0.010	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromofluorobenzene	0.0364	0.0400	91	60-140

Notes:

Parameter H-C Range
Gasoline C6-C10
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 5ml Final Volume : 5ml
Prepared by : SCerva Analyzed by : SCerva

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 5030B/8015B

MATRIX : WATER		% MOISTURE:NA
DILUTION FACTOR: 1	1	1
SAMPLE ID : MBLK1W	LCS1W	LCD1W
LAB SAMPLE ID : VGH7A02B	VGH7A02L	VGH7A02C
LAB FILE ID : AA06005A	AA06006A	AA06007A
DATE PREPARED : 01/06/22 15:39	01/06/22 16:14	01/06/22 16:48
DATE ANALYZED : 01/06/22 15:39	01/06/22 16:14	01/06/22 16:48
PREP BATCH : 22VGH7A02	22VGH7A02	22VGH7A02
CALIBRATION REF: AA06003A	AA06003A	AA06003A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.457	91	0.500	0.467	93	2	60-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0478	120	0.0400	0.0456	114	70-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978210
BATCH NO. : 22A033
METHOD : 5030B/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201040139                       202201040139MS  202201040139MSD
LAB SAMPLE ID : A033-01                          A033-01M      A033-01S
LAB FILE ID  : AA06008A                          AA06009A      AA06010A
DATE PREPARED : 01/06/22 17:22                   01/06/22 17:57  01/06/22 18:31
DATE ANALYZED : 01/06/22 17:22                   01/06/22 17:57  01/06/22 18:31
PREP BATCH   : 22VGH7A02                          22VGH7A02     22VGH7A02
CALIBRATION REF: AA06003A                         AA06003A      AA06003A
=====
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.438	88	0.500	0.449	90	2	50-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0447	112	0.0400	0.0439	110	60-140

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

978568

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

SDG#: 22A034

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 978568

SDG : 22A034

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

A total of two(2) water samples were received on 01/06/22 to be analyzed for Total Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA004WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for Diesel was within LCS QC limits in DSA004WL. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG. One(1) set of MS/MSD was analyzed. Diesel was within MS QC limits in 22A033-01M/22A033-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 978568

SDG : 22A034

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

A total of two(2) water samples were received on 01/06/22 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA004WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for JP5 was within LCS QC limits in J5A004WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. JP5 was within MS QC limits in 22A034-01M/22A034-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 978568

SDG : 22A034

METHOD 3520C/8015B PETROLEUM HYDROCARBONS BY EXTRACTION

A total of two(2) water samples were received on 01/06/22 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA004WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for JP8 was within LCS QC limits in J8A004WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. JP8 was within MS QC limits in 22A034-03M/22A034-03S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project     : 978568
=====
SDG NO.    : 22A034
Instrument ID : D5
=====

```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis Date/Time	Extraction Date/Time	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
					WATER				
MBLK1W	DSA004WB	1	NA	01/07/2213:48	01/06/2214:45	LA07009A	LA07004A	22DSA004W	Method Blank
LCS1W	J5A004WL	1	NA	01/07/2214:23	01/06/2214:45	LA07011A	LA07004A	22DSA004W	Lab Control Sample (LCS)
202201050306	A034-01	1	NA	01/07/2215:52	01/06/2214:45	LA07016A	LA07004A	22DSA004W	Field Sample
202201050306MS	A034-01M	1	NA	01/07/2216:10	01/06/2214:45	LA07017A	LA07004A	22DSA004W	Matrix Spike Sample (MS)
202201050306MSD	A034-01S	1	NA	01/07/2216:27	01/06/2214:45	LA07018A	LA07004A	22DSA004W	MS Duplicate (MSD)
202201050308	A034-03	1	NA	01/07/2216:45	01/06/2214:45	LA07019A	LA07004A	22DSA004W	Field Sample

```

FN          - Filename
% Moist    - Percent Moisture

```

LAB CHRONICLE
PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL
Project     : 978568
SDG NO.    : 22A034
Instrument ID : D5
=====
  
```

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis Date/Time	Extraction Date/Time	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
					WATER				
MBLK1W	DSA004WB	1	NA	01/07/2213:48	01/06/2214:45	LA07009A	LA07005A	22DSA004W	Method Blank
LCS1W	J8A004WL	1	NA	01/07/2214:41	01/06/2214:45	LA07012A	LA07005A	22DSA004W	Lab Control Sample (LCS)
202201050306	A034-01	1	NA	01/07/2215:52	01/06/2214:45	LA07016A	LA07005A	22DSA004W	Field Sample
202201050308	A034-03	1	NA	01/07/2216:45	01/06/2214:45	LA07019A	LA07005A	22DSA004W	Field Sample
202201050308MS	A034-03M	1	NA	01/07/2217:21	01/06/2214:45	LA07021A	LA07005A	22DSA004W	Matrix Spike Sample (MS)
202201050308MSD	A034-03S	1	NA	01/07/2217:39	01/06/2214:45	LA07022A	LA07005A	22DSA004W	MS Duplicate (MSD)

```

FN          - Filename
% Moist     - Percent Moisture
  
```

SAMPLE RESULTS

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:50
Project     : 978568                     Date Received: 01/06/22
Batch No.   : 22A034                     Date Extracted: 01/06/22 14:45
Sample ID   : 202201050306              Date Analyzed: 01/07/22 15:52
Lab Samp ID: 22A034-01                   Dilution Factor: 1
Lab File ID: LA07016A                    Matrix: WATER
Ext Btch ID: 22DSA004W                   % Moisture: NA
Calib. Ref.: LA07004A                    Instrument ID: D5
=====
  
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.055	0.028

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.485	0.550	88	60-130
Hexacosane	0.136	0.138	99	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 910ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:50
Project    : 978568                      Date Received: 01/06/22
Batch No.  : 22A034                      Date Extracted: 01/06/22 14:45
Sample ID  : 202201050306                Date Analyzed: 01/07/22 15:52
Lab Samp ID: 22A034-01                   Dilution Factor: 1
Lab File ID: LA07016A                    Matrix: WATER
Ext Btch ID: 22DSA004W                   % Moisture: NA
Calib. Ref.: LA07005A                    Instrument ID: D5
=====
    
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
JP8	ND	0.055	0.028	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.485	0.550	88	60-130
Hexacosane	0.136	0.138	99	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP8 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 910ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:30
Project     : 978568                      Date Received: 01/06/22
Batch No.   : 22A034                      Date Extracted: 01/06/22 14:45
Sample ID   : 202201050308              Date Analyzed: 01/07/22 16:45
Lab Samp ID: 22A034-03                  Dilution Factor: 1
Lab File ID: LA07019A                   Matrix: WATER
Ext Btch ID: 22DSA004W                  % Moisture: NA
Calib. Ref.: LA07003A                   Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
Diesel	ND	0.030	0.015	
Motor Oil	ND	0.059	0.030	

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.465	0.590	79	60-130
Hexacosane	0.148	0.148	101	60-130

Notes:
Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 850ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/04/22 09:30
Project     : 978568                      Date Received: 01/06/22
Batch No.   : 22A034                      Date Extracted: 01/06/22 14:45
Sample ID   : 202201050308               Date Analyzed: 01/07/22 16:45
Lab Samp ID: 22A034-03                   Dilution Factor: 1
Lab File ID: LA07019A                    Matrix: WATER
Ext Btch ID: 22DSA004W                   % Moisture: NA
Calib. Ref.: LA07004A                    Instrument ID: D5
=====
  
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.059	0.030

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.465	0.590	79	60-130
Hexacosane	0.148	0.148	101	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP5 C8-C18
 Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
 Sample Amount : 850ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL      Date Collected: 01/04/22 09:30
Project     : 978568                        Date Received: 01/06/22
Batch No.   : 22A034                        Date Extracted: 01/06/22 14:45
Sample ID   : 202201050308                 Date Analyzed: 01/07/22 16:45
Lab Samp ID: 22A034-03                     Dilution Factor: 1
Lab File ID: LA07019A                      Matrix: WATER
Ext Btch ID: 22DSA004W                     % Moisture: NA
Calib. Ref.: LA07005A                      Instrument ID: D5
=====
    
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP8	ND	0.059	0.030

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.465	0.590	79	60-130
Hexacosane	0.148	0.148	101	60-130

Notes:
 RL : Reporting Limit
 Parameter H-C Range
 JP8 C8-C18
 Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
 Sample Amount : 850ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

QC SUMMARIES

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/06/22 14:45
Project    : 978568                      Date Received: 01/06/22
Batch No.  : 22A034                      Date Extracted: 01/06/22 14:45
Sample ID  : MBLK1W                      Date Analyzed: 01/07/22 13:48
Lab Samp ID: DSA004WB                   Dilution Factor: 1
Lab File ID: LA07009A                   Matrix: WATER
Ext Btch ID: 22DSA004W                  % Moisture: NA
Calib. Ref.: LA07003A                   Instrument ID: D5
=====

```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
Diesel	ND	0.025	0.012	
Motor Oil	ND	0.050	0.025	

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.406	0.500	81	60-130
Hexacosane	0.117	0.125	93	60-130

Notes:
Parameter H-C Range
Diesel C10-C24
Motor Oil C24-C36
Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
Sample Amount : 1000ml Final Volume : 5ml
Prepared by : JMuert Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSA004WB DSA004WL
LAB FILE ID : LA07009A LA07010A
DATE PREPARED : 01/06/22 14:45 01/06/22 14:45
DATE ANALYZED : 01/07/22 13:48 01/07/22 14:06
PREP BATCH : 22DSA004W 22DSA004W
CALIBRATION REF: LA07003A LA07003A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Diesel	ND	2.50	2.29	92	50-130

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.536	107	60-130
Hexacosane	0.125	0.122	98	60-130

MB: Method Blank sample LCS: Lab Control Sample

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/06/22 14:45
Project    : 978568                      Date Received: 01/06/22
Batch No.  : 22A034                      Date Extracted: 01/06/22 14:45
Sample ID  : MBLK1W                      Date Analyzed: 01/07/22 13:48
Lab Samp ID: DSA004WB                   Dilution Factor: 1
Lab File ID: LA07009A                   Matrix: WATER
Ext Btch ID: 22DSA004W                  % Moisture: NA
Calib. Ref.: LA07004A                  Instrument ID: D5
=====
  
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)	
JP5	ND	0.050	0.025	
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.406	0.500	81	60-130
Hexacosane	0.117	0.125	93	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSA004WB J5A004WL
LAB FILE ID : LA07009A LA07011A
DATE PREPARED : 01/06/22 14:45 01/06/22 14:45
DATE ANALYZED : 01/07/22 13:48 01/07/22 14:23
PREP BATCH : 22DSA004W 22DSA004W
CALIBRATION REF: LA07004A LA07004A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
JP5	ND	2.50	2.16	86	30-160

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.541	108	60-130
Hexacosane	0.125	0.121	97	60-130

MB: Method Blank sample LCS: Lab Control Sample

METHOD 3520C/8015B
 PETROLEUM HYDROCARBONS BY EXTRACTION

```

=====
Client      : EUROFINS EATON ANALYTICAL   Date Collected: 01/06/22 14:45
Project    : 978568                       Date Received: 01/06/22
Batch No.  : 22A034                       Date Extracted: 01/06/22 14:45
Sample ID  : MBLK1W                       Date Analyzed: 01/07/22 13:48
Lab Samp ID: DSA004WB                     Dilution Factor: 1
Lab File ID: LA07009A                     Matrix: WATER
Ext Btch ID: 22DSA004W                    % Moisture: NA
Calib. Ref.: LA07005A                     Instrument ID: D5
=====
    
```

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP8	ND	0.050	0.025

SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY	QC LIMIT
Bromobenzene	0.406	0.500	81	60-130
Hexacosane	0.117	0.125	93	60-130

Notes:

RL : Reporting Limit
 Parameter H-C Range
 JP8 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.
 Sample Amount : 1000ml Final Volume : 5ml
 Prepared by : JMuert Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 3520C/8015B

```
=====
MATRIX      : WATER           % MOISTURE:NA
DILUTION FACTOR: 1           1
SAMPLE ID   : MBLK1W         LCS1W
LAB SAMPLE ID : DSA004WB     J8A004WL
LAB FILE ID  : LA07009A     LA07012A
DATE PREPARED : 01/06/22 14:45 01/06/22 14:45
DATE ANALYZED : 01/07/22 13:48 01/07/22 14:41
PREP BATCH   : 22DSA004W    22DSA004W
CALIBRATION REF: LA07005A   LA07005A
```

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
JP8	ND	2.50	2.08	83	30-160

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.499	100	60-130
Hexacosane	0.125	0.119	95	60-130

MB: Method Blank sample LCS: Lab Control Sample

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978210
BATCH NO. : 22A033
METHOD : 3520C/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201040139                       202201040139MSD
LAB SAMPLE ID : 22A033-01                         22A033-01S
LAB FILE ID  : LA07013A                          LA07014A
DATE PREPARED : 01/06/22 14:45                   01/06/22 14:45
DATE ANALYZED : 01/07/22 14:59                   01/07/22 15:34
PREP BATCH   : 22DSA004W                         22DSA004W
CALIBRATION REF: LA07003A                        LA07003A
=====

```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Diesel	ND	2.78	2.56	92	2.85	2.69	94	5	50-130	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.555	0.573	103	0.570	0.593	104	60-130
Hexacosane	0.139	0.142	102	0.142	0.144	101	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 3520C/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201050306                       202201050306MSD
LAB SAMPLE ID : 22A034-01                         22A034-01S
LAB FILE ID  : LA07016A                           LA07018A
DATE PREPARED : 01/06/22 14:45                   01/06/22 14:45
DATE ANALYZED : 01/07/22 15:52                   01/07/22 16:27
PREP BATCH   : 22DSA004W                          22DSA004W
CALIBRATION REF: LA07004A                        LA07004A
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JP5	ND	2.72	2.36	87	2.78	2.51	90	6	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.545	0.681	125	0.555	0.552	99	60-130
Hexacosane	0.136	0.173	127	0.139	0.125	90	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 978568
BATCH NO. : 22A034
METHOD : 3520C/8015B

```

=====
MATRIX      : WATER                               % MOISTURE:NA
DILUTION FACTOR: 1                               1
SAMPLE ID   : 202201050308                       202201050308MSD
LAB SAMPLE ID : 22A034-03                         22A034-03S
LAB FILE ID  : LA07019A                          LA07022A
DATE PREPARED : 01/06/22 14:45                   01/06/22 14:45
DATE ANALYZED : 01/07/22 16:45                   01/07/22 17:39
PREP BATCH   : 22DSA004W                         22DSA004W
CALIBRATION REF: LA07005A                       LA07005A
=====
  
```

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JPB	ND	2.95	2.77	94	2.85	2.70	95	3	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.590	0.596	101	0.570	0.576	101	60-130
Hexacosane	0.148	0.131	89	0.142	0.132	93	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate